

CITY OF DETROIT
SPECIAL PROVISION
FOR
SIDEWALK, CONC, _____ INCH, MODIFIED

1 of 1

DET:NH:MS

Revised : 10-03-06

DESCRIPTION:

Concrete sidewalk of the thickness specified shall be constructed in accordance with Section 803 of the 2003 Michigan Department of Transportation (MDOT) Standard Specifications for Construction. Sidewalk cross slopes shall be 2% sloping down towards the street. Concrete Sidewalk shall normally be constructed to a 4-inch thickness. Use of 6-inch thick concrete sidewalk shall be as follows:

The first flag of concrete sidewalk adjacent to commercial driveways and alley pavement shall be 6 inches in thickness.

At street returns adjacent to the right side of a turning movement, concrete sidewalk constructed within 3 feet of the face of curb shall be 6-inch thickness. The Engineer will determine the limit of this item so that unusual jointing with the adjacent 4-inch thick sidewalk will not occur.

Where the Engineer determines that sidewalk shall be removed to facilitate the reconstruction of a residential driveway, the concrete sidewalk within the driveway limits shall be 6 inches in thickness.

METHOD MEASUREMENT AND BASIS OF PAYMENT:

"Sidewalk, Conc, _inch, Modified" of the thickness specified shall be measured and paid for as specified in Subsection 803.04 of the 2003 MDOT Standard Specifications for construction. Any excavation or granular backfill 4 inches or less required to construct the walk shall be included in this item of work and will not be paid for separately,

Item

Pay Unit

Sidewalk, Conc, 4 inch, Modified

Square Foot

Sidewalk, Conc, 6 inch, Modified

Square Foot