CITY OF DETROIT

INTER-OFFICE CORRESPONDENCE

TO: Mr. Frank E. Simpson DATE January 7, 1957

FROM: Mr. Jos. P. Wolff SUBJECT: Building Code Bulletins

Until further notice, bulletins pertaining to the old Building Code listed below by number shall remain in effect as written and shall apply equally to the provisions of the new Building Code. Other bulletins pertaining to the Zoning Ordinance and Building Bureau policy will be retained by the Building Bureau at their discretion.

Bulletin Numbers

127	251	333
140	257	335
166	294	346
175	300	349
189	308	353
200	324	354
204	327	355
240	329	

CITY OF DETROIT

INTER-OFFICE CORRESPONDENCE

TO: Messrs. F. E. Simpson, J. M. Fink DATE January 16, 1957

FROM: Mr. W. J. Robinson SUBJECT: Additions to Dwellings within Six (6) Feet of Interior Lot Lines

Commissioner Wolff has ruled that additions to existing frame dwellings do not come within the purview of Section 305.1 for three-quarter hour fire protection, provided that the addition is at least three feet from the lot line and six feet from a frame building on an adjoining lot. This is in line with the definition of "alteration" and Section 106.1. Additions to dwellings less than three feet from interior lot lines shall conform to the requirements of Section 305.1.

This ruling does not apply to buildings moved from one location to another which must comply with Section 1324.0, Ordinance 762-E and Section 305.1.