



MANUFACTURER'S CERTIFICATE OF COMPLIANCE

Encore Wire Corporation's type **XHHW-2** insulated 1000-volt building wire is produced in the United States of America using accepted practices and quality assurance procedures to comply with specifications of regulatory agencies.

Products Description: **XHHW-2 Conductors – UL Listed E177544**

Specifications: ASTM Class – B-3, B-8, B-787
Underwriters Laboratories Standard UL-44, UL-1581,
UL- 2556
Canadian C-UL RW90 Listed
NEMA WC-70/ICEA S-95-658
UL 1685 Cable Tray Flame Test (1/0 AWG and larger) *
ICEA T-29-520 (210,000 Btu/hr.) Flame Test *
American National Standards Institute
Federal Specification A-A 59544
NFPA 70: Nation Electrical Code 2020
RoHS Compliant
ARRA 2009 Section 1605; Buy American Compliant

*Optional

I certify that the above listed material complies with requirements including applicable standards set forth in this certification. If you have any question or comments, please give me a call. (800) 962-9473 Ext. 637.

Sincerely,

Paul W. Abernathy, CMECP.
Manager of Codes & Standards
Encore Wire Corporation
Research and Development Center
1324 Millwood Rd.
McKinney, TX 75069
800-962-9473 Ext. 637
Paul.Abernathy@encorewire.com