

**INDEPENDENT ASSURANCE
CONCRETE SAMPLING AND TESTING**

File 306 _____

DISTRIBUTION: IA Coordinator, Inspector, ProjectWise, Construction Field Services Division.

CONTROL SECTION 82000	JOB NUMBER 205935A	REGION METRO REGION	DATE 09/02/20
INSPECTOR NAME & (Agency / Company) WILLIAM FAELDUNA - SOMAT ENGINEERING		MCA CERTIFICATION / EXPIRATION MCA L1 EXPIRES 04/15/2022	
PROJECT ENGINEER NAME & (Agency / Company) M. RICHTER, PE - HRC			
MDOT INDEPENDENT ASSURANCE TESTER OR (Representative) & OFFICE JOHN M WATSON III - MDOT METRO LAB: MCA LEVEL 1 EXPIRES 04/15/2022 ACI EXPIRES 05/02/2024			

FIELD TESTING

AIR METER / EQUIPMENT CALIBRATION DATE SOMAT PAM #16 6/10/2020 - 9/10/2020		CONDITION GOOD	
	INSPECTOR'S RESULT	IA TESTER'S RESULT ("W" if witnessed)	
AIR CONTENT	5.6%	"W"	
SLUMP	3 1/2" INCHES	"W"	
PROCEDURES WITNESSED ☒ Satisfactory ☐ Unsatisfactory ☐ See Remarks			
CONC. TEMP. 81 F	AIR TEMP 73 F	CYLINDERS MADE ☐ Yes ☒ No	BEAMS MADE ☐ Yes ☒ No

LAB STRENGTH TESTING

COMPRESSION MACHINE MODEL & CALIBRATION DATE				CONDITION			
RESULTS	HEIGHT	DIAMETER	C.F.	TOTAL LOAD	P.S.I.	BREAK TYPE	AVERAGE
CYLINDER 1							
CYLINDER 2							
CURE ROOM ☐ Yes ☐ No		TEMP. F		WATER BATH ☐ Yes ☐ No		TEMP. F	
PROCEDURES WITNESSED ☐ Satisfactory ☐ Unsatisfactory ☐ See Remarks							

REMARKS

LOCATION: PURITAN & MURRY HILL

ACF OF 0.2 WAS APPLIED BY INSPECTOR.

CONCRETE MEETS SPECIFICATIONS.

IA INSPECTOR (Signature)

John M. Watson IIIJohn M. Watson III
Sep 11 2020 5:21 PMDATE
09/02/20