



7125 Orchard Lake Rd, Suite 104, West Bloomfield, MI 48322
Tel: 248-562-7129 Fax: 248-562-7237

CONCRETE QA CORRELATION

DATE: 4/1/2020MDOT CONTROL SECTION: N/AMDOT JOB NUMBER: N/ASOMAT JOB NUMBER: 2019086CPROJECT NAME: Major Road Fed-AidCITY: Detroit, MICLIENT: HRCPROJECT ENGINEER: Pamela Lemme (CED)INSPECTOR: Marty (HRC)CONTRACTOR: MerloQC COMPANY: CTIQC TESTER: Gill

CONCRETE INFORMATION

CONCRETE COMPANY:	Superior Materials	TRUCK NUMBER:	4941
MIX DESIGN #:	P155E7CNA002	PLANT LOCATION (CITY):	2
CONCRETE GRADE:	P1	TOTAL QUANTITY (CYDS):	24
PWL/NON-PWL:	NON-PWL	QUANTITY AT SAMPLE (CYDS):	3

POUR LOCATION (STATION, STRUCTURE, ETC...)

Ada ramps on McClellan from Gratiot to Jefferson

TEST RESULTS

	QC (CONTRACTOR)	QA (SOMAT)	TOLERANCE	MEETS TOLERANCE (Y/N)
SAMPLE TIME (Hrs/Min):	10:33am			
AIR CONTENT (%):	5.80	5.50	+/- 0.8 PERCENT	YES
CONCRETE TEMP. (°F):	64	63	+/- 2.0 DEGREES	YES
AIR TEMP. (°F):	45	45		

REMARKS:

--

FIELD REPRESENTATIVE:	Zachary Brindley	DATE:	4/1/2020
PROJECT MANAGER(s):	Steve Drummond	DATE:	

*All results noted in this report relate only to items inspected or tested by Somat Engineering, Inc. and/or Somat Engineering of Ohio, Inc. (Somat). This report shall not be reproduced, except in full, without the prior written approval of Somat.