

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR MERID CONSTRUCTION GENERAL NAME OF PROJECT MDOT - VARIOUS DETROIT
SUBCONTRACTOR _____ CONTROL SECTION ID - JOB NUMBER _____

CONCRETE SUPPLIER SUPERIOR MATERIALS ROUTE LAFAYETTE BTW MT ELLIOT
MAXIMUM TIME 90 MINUTES STRUCTURE NUMBER E GRAND BLVD

WEATHER SUNNY A.M. _____ P.M. _____ REPORT NUMBER W/O 1112 DATE 6-29-20

MAX. WATER ADDED PER CYD GALLONS _____ REASON: 5/ESIDE WALK
BEAMS/CYLINDERS MADE (Sta, Time, #, etc) MT ELLIOT + LAFAYETTE CURING COMPND. USED GALLONS _____

Intended Air 5.5 % to 8.5 % TEMPERATURES - AIR - SLUMP Intended Slump 0 " to 5 "

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
① 9:34	73	84	6.5	3.5	4						
② 11:49	78	87	6.9	5.0	4						

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder

COMMENTS SAMPLED FROM TRUCK CHUTE

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS (Use back if necessary) ① TICKET - 2505838 PISSERCQA032 ② TICKET - 2505957 PISSERCQA032

MIX OR STREET TECHNICIAN G. GUTMAN DATE 6-29-20

