

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR <i>Merlo Const</i>	GENERAL NAME OF PROJECT <i>MDOT Various Rd Improvement Oct MI</i>
SUBCONTRACTOR	CONTROL SECTION ID - JOB NUMBER <i>82000-205935</i>
CONCRETE SUPPLIER <i>Superior Materials</i>	ROUTE <i>McClellan Street</i>
MAXIMUM TIME <i>90 min</i>	STRUCTURE NUMBER
WEATHER <i>partly sunny 53°</i> A.M. _____ P.M.	REPORT NUMBER _____ DATE <i>Wed 4-08-2020</i>

MAX. WATER ADDED PER CYD GALLONS	REASON:	BEAMS/CYLINDERS MADE (Sta, Time, #, etc.) <i>Side walk at #4209 8:15 AM</i>	CURING COMPND. USED GALLONS <i>White curing compound sprayed</i>
-------------------------------------	---------	--	--

Intended Air *5.5* % to *8.0* % TEMPERATURES - AIR - SLUMP Intended Slump " to "

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
<i>8:15 AM</i>	<i>53°</i>	<i>62°</i>	<i>5.9</i>	<i>4 1/2"</i>	<i>1 set of 4 cyl molded</i>						
<i>10:30 AM</i>	<i>58°</i>	<i>67°</i>	<i>5.6</i>	<i>4"</i>							
<i>1:05 PM</i>	<i>61°</i>	<i>69°</i>	<i>6.2</i>	<i>5"</i>							

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder

COMMENTS

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS
(Use back if necessary)

#2436417 8:15 AM 10.00 yds #2486434 10:30 AM 10.00 yds

** pour from concrete truck chute*

MIX OR STREET TECHNICIAN *Mike Potts* DATE *4-08-2020*

70.00 yards placed

