

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

FA20W00482

CONTRACTOR <u>Merlo Const</u>		GENERAL NAME OF PROJECT <u>MDOT Various Rd Improvement Oct 2017</u>	
SUBCONTRACTOR		CONTROL SECTION ID - JOB NUMBER	
CONCRETE SUPPLIER <u>Superior Materials</u>		ROUTE <u>McDellan & Gratiot</u>	
MAXIMUM TIME <u>90 min</u>		STRUCTURE NUMBER <u>Thru</u>	
WEATHER <u>Cloudy 40°</u> A.M. _____ P.M. _____		REPORT NUMBER _____ DATE <u>4-09-2020</u>	
MAX. WATER ADDED PER CYD GALLONS		REASON:	

BEAMS/CYLINDERS MADE (Sta, Time, #, etc.) <u>7:30 AM</u>						CURING COMPND USED <u>White Spring Compound Sprayed</u>					
# <u>3209 Sidewalk & ADA Ramp</u>											
Intended Air <u>515</u> % to <u>8</u> %						TEMPERATURES - AIR - SLUMP Intended Slump _____ " to _____ "					
TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
<u>7:30 AM</u>	<u>40°</u>	<u>61°</u>	<u>5.6</u>	<u>4 3/4"</u>	<u>2 cylinders</u>						
<u>9:00 AM</u>	<u>41°</u>	<u>58°</u>	<u>5.6</u>	<u>4 1/2"</u>							

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder

Pat Potts
4-9-2020
Vid & Accepted

COMMENTS

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS (Use back if necessary)		DATE	
<u>P155ERCQA032</u> <u>#2486532 10.00 yards</u> <u>#2486563 10.00 yards</u> <u>9:30 AM</u> <u>9:00 AM</u> <u>30.00 yards placed</u> <u>Mike Potts</u>		<u>4-09-2020</u>	

