

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR MELIO CONSTRUCTION		GENERAL NAME OF PROJECT M.DOT - VARIOUS DETROIT	
SUBCONTRACTOR		CONTROL SECTION ID - JOB NUMBER	
CONCRETE SUPPLIER SUPERIOR MATERIALS		ROUTE LAFAYETTE BTW MT ELLIOT & GRAND BLVD	
MAXIMUM TIME 90 MINUTES		STRUCTURE NUMBER	
WEATHER SUNNY A.M. P.M.		REPORT NUMBER W/O 1112	DATE 6-29-20

MAX. WATER ADDED PER CYD GALLONS	REASON: 0.5% ESIDE WALK
BEAMS/CYLINDERS MADE (Sta, Time, #, etc.) MT ELLIOT + LAFAYETTE	CURING COMPND. USED GALLONS

Intended Air **5.5 %** to **8.5 %** TEMPERATURES - AIR - SLUMP Intended Slump **0 "** to **5 "**

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
① 9:34	73	84	6.5	3.5	4						
② 11:49	78	87	6.9	5.0	4						

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder

COMMENTS **SAMPLED FROM TRUCK CHUTE**

ITEM OR CODE NO.	SIA TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS (Use back if necessary) ① **TICKET - 2505838 PISSERCQA032** ② **TICKET - 2505957 PISSERCQA032**

MIX OR STREET TECHNICIAN **G. Guzman** DATE **6-29-20**

