

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR		GENERAL NAME OF PROJECT <i>Joseph Campau - McLean</i>	
SUBCONTRACTOR <i>Marlo</i>		CONTROL SECTION ID - JOB NUMBER <i>119204 0025</i>	
CONCRETE SUPPLIER <i>SUPERIOR (PISSE 7CNA002)</i>		ROUTE <i>North Bound</i>	
MAXIMUM TIME <i>90</i>		STRUCTURE NUMBER	
WEATHER <i>Cloudy</i> A.M. <i>Cloudy</i> P.M.		REPORT NUMBER	
MAX. WATER ADDED PER CYD GALLONS		DATE <i>7-22-20</i>	
REASON:			

BEAMS/CYLINDERS MADE (Sta, Time, #, etc.) *82000-205935* CURING COMPND. USED GALLONS

TEMPERATURES - AIR - SLUMP						Intended Slump <i>3</i> " to <i>5</i> "					
Intended Air <i>5.5</i> % to <i>8.0</i> %											
TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
① 810AM	75	86	6.4	5	4						
955AM	75	86	6.8	5	—						
② 1205pm	76	86	6.8	5 1/2	4						
210pm	76	86	6.6	5	—						
505pm	74	88	6.8	5	—						

	LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder
①	Sidewalk at McPherson McPherson						
②	Sidewalk at McLean + Meade						
	Truck # 1392 (90) Rejected Time Out						

COMMENTS

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS
(Use back if necessary)

MIX OR STREET TECHNICIAN

DATE
7-22-20