

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR

Merlo Construction

SUBCONTRACTOR

CONCRETE SUPPLIER

Superior Materials

MAXIMUM TIME

40 minutes

WEATHER

partly cloudy A.M. partly cloudy P.M.

MAX. WATER ADDED PER CYD
GALLONS

REASON:

BEAMS/CYLINDERS MADE (Sta, Time, #, etc.)

① SE ADA ramps at Verner & Joseph Campau
② NW ADA ramps at Verner & Elery

CURING COMPND. USED
GALLONS

Intended Air 5.5 % to 8.5 % TEMPERATURES - AIR - SLUMP Intended Slump 0 " to 6 "

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT-%	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
① 7:10am	79°F	87°F	5.6%	5"	4						
② 1:00pm	87°F	77°F	7.6%	4.75"	4						

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder

COMMENTS: poured by truck chute

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS
(Use back if necessary)

① ticket 2515173
PISSER (QA032)

② ticket 2515397
PISSER (QA032)
*air added on site

MIX OR STREET TECHNICIAN

Mallory Grager Mary Grager

DATE 7/27/20

