

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR <u>Merio Construction</u>		GENERAL NAME OF PROJECT <u>MDOT-Various Detroit</u>	
SUBCONTRACTOR		CONTROL SECTION ID - JOB NUMBER	
CONCRETE SUPPLIER <u>Superior Materials</u>		ROUTE <u>Woodmere St</u>	
MAXIMUM TIME <u>90 minutes</u>		STRUCTURE NUMBER	
WEATHER <u>Partly cloudy</u> A.M. <u>partly cloudy</u> P.M.		REPORT NUMBER	DATE <u>7/28/20</u>

MAX. WATER ADDED PER CYD GALLONS	REASON:	<u>(3) SE corner ADA ramps/ sidewalk at Woodmere & Richard</u>	
BEAMS/CYLINDERS MADE (Sta, Time, #, etc.)		<u>(1) SE corner curb at Woodmere & Richard</u> <u>(2) SE corner curb at Woodmere & Lawndale</u>	
Intended Air <u>5.5</u> % to <u>8.5</u> %		TEMPERATURES - AIR - SLUMP Intended Slump <u>0</u> " to <u>3</u> "	

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
① 11:00am	80°F	74°F	6.8%	3"	4						
② 12:05pm	83°F	76°F	6.1%	3"	-						
③ 2:30pm	85°F	84°F	6.4%	5.25"	4						

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder

COMMENTS: *poured by truck chute

*Load 1 (ticket 2515729) rejected, temp 290°F

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS (Use back if necessary) ① ticket 2515856 ② ticket 2515910 ③ ticket 2516020
P155E7CQA032 P155E7CQA032 P155ERCQA032

MIX OR STREET TECHNICIAN <u>Mallory Grager</u>	DATE <u>7/28/20</u>
---	------------------------

