

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR		GENERAL NAME OF PROJECT VARIOUS PROJECTS	
SUBCONTRACTOR MERLO CONSTRUCTION		CONTROL SECTION ID - JOB NUMBER	
CONCRETE SUPPLIER SUPERIOR MATERIALS		ROUTE LINWOOD - OAKMAN + CLEMENTS	
MAXIMUM TIME 90 MIN		STRUCTURE NUMBER CURB + SIDEWALK ADA 3/4 SIDE OF LINWOOD	
WEATHER CLR 57 A.M. CLR 66 P.M.		REPORT NUMBER 1844	DATE 9.17.20

MAX. WATER ADDED PER CYD
GALLONS

REASON:

BEAMS/CYLINDERS MADE (Sta, Time, #, etc.)

CURING COMPND. USED
GALLONS **3**

Intended Air **5.5** % to **8.5** % TEMPERATURES - AIR - SLUMP Intended Slump **0-3** " to **0-5**

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
① 9:05	57	73	6.4	225	4						
② 12:05	64	74	6.4	3.0	—						
③ 1:20	66	80	7.6	5.0	4						

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder
①	TICKET - 2534372					CURB 3/4 SIDE LINWOOD + OAKMAN
②	TICKET - 2534584					SIDEWALK ADA 3/4 SIDE LINWOOD + OAKMAN
③	TICKET - 2534652					SIDEWALK ADA - 3/4 SIDE LINWOOD + FLEET

COMMENTS

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS
(Use back if necessary)

60 - TOTAL YDS

③ **PISSERUQA032 - 30 YDS**

SAMPLE FROM TRUCK CHUTE

MIX OR STREET TECHNICIAN

① **PISSERUQA032 - 30 YD**
②

G GUZMAN 9.17.20

AW 9/17/20

