

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR		GENERAL NAME OF PROJECT VARIOUS PROJECTS	
SUBCONTRACTOR MERIO CONSTRUCTION		CONTROL SECTION ID - JOB NUMBER SIDEWALK ADA S/W SIDE	
CONCRETE SUPPLIER SUPERIOR MATERIALS		ROUTE LINWOOD - PASADENA + CLEMENTS	
MAXIMUM TIME 90 MIN		STRUCTURE NUMBER + CURB	
WEATHER CLK 46 A.M. P.M.		REPORT NUMBER 1863	DATE 9.21.20

MAX. WATER ADDED PER CYD GALLONS	REASON:	BEAMS/CYLINDERS MADE (Sta, Time, #, etc.)	CURING COMPND. USED GALLONS
-------------------------------------	---------	---	--------------------------------

Intended Air 55 % to 85 % TEMPERATURES - AIR - SLUMP Intended Slump 0-5" to 0-5"

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
① 840	46	69	6.2	4.0	4						
② 1200	64	77	6.8	4.75	—						
③ 1:40	68	79	6.8	2.0	4						

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder
①	TICKET- 2535915		SIDEWALK + ADA S/W CORNER		LINWOOD + PASADENA	
②	TICKET- 2536138		SIDEWALK + ADA S/W CORNER		LINWOOD + CLEMENTS	
③	TICKET- 2536225		N/CURB ON BAGLEY 100' WEST OF TRUMBLE			

COMMENTS

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS
(Use back if necessary)

54 TOTAL YRS

SAMPLE FROM TRUCK CHUTE

MIX OR STREET TECHNICIAN

① MIX - PISSERCQA032734 F. GUZMAN

DATE 9.21.20

②

③ MIX - PISSE7CQA032 - 2040

