

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR		GENERAL NAME OF PROJECT VARIOUS PROJECTS	
SUBCONTRACTOR MERLO CONSTRUCTION		CONTROL SECTION ID - JOB NUMBER	
CONCRETE SUPPLIER SUPERIOR MATERIALS		ROUTE W/B BAGLEY - ROSA PARKS + 24TH	
MAXIMUM TIME 90 MIN		STRUCTURE NUMBER SIDEWALK + ADA / BUS STOP + BAGLEY + WABASH	
WEATHER CLC 55 A.M. Sunny 76 P.M.		REPORT NUMBER 1882	DATE 9-23-20
MAX. WATER ADDED PER CYD GALLONS		REASON:	

BEAMS/CYLINDERS MADE (Sta, Time, #, etc.)

CURING COMPND. USED GALLONS

Intended Air **5.5** % to **8.5** % TEMPERATURES - AIR - SLUMP Intended Slump **0** " to **5** "

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
① 8:30	55	70	7.2	6.0	4						
② 10:45	62	71	6.8	5.0	—						
③ 1:10	75	81	7.6	5.0	4						
④ 5:05	79	83	6.8	5.0	—						

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder
①	TICKET- 2537054	-	N SIDEWALK + ADA -	BAGLEY + 14TH		
②	TICKET- 2537214	-	N SIDEWALK + ADA -	BAGLEY + 16TH		
③	TICKET- 2537381	-	N SIDEWALK + ADA -	BAGLEY + 18TH		
④	TICKET 2537547	-	S SIDEWALK -	BAGLEY + WABASH		

COMMENTS

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS
(Use back if necessary)

90 - YDS.

MIX OR STREET TECHNICIAN
MIX- PISSIERCNAO 2 ①

DATE **9-23-20**

G. SUZMAN
10/1/2020

