

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR		GENERAL NAME OF PROJECT VARIOUS PROJECTS	
SUBCONTRACTOR MEALO CONSTRUCTION		CONTROL SECTION ID - JOB NUMBER	
CONCRETE SUPPLIER SUPERIOR MATERIALS		ROUTE N1B LINWOOD - DAVIDSON + OAKMAN	
MAXIMUM TIME 40 MIN		STRUCTURE NUMBER CURB - SIDEWALK + ADA	
WEATHER CLR 62 A.M. SUNNY 75 P.M.		REPORT NUMBER 1898	DATE 9-24-20
MAX. WATER ADDED PER CYD GALLONS		REASON:	

BEAMS/CYLINDERS MADE (Sta, Time, #, etc.)

CURING COMPND: USED GALLONS **(2) (3)**

Intended Air **55** % to **8.5** %

TEMPERATURES - AIR - SLUMP

Intended Slump **0-3** to **5"**

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS
① 10:00	62	78	6.4	3.0	4						
② 215	77	84	6.1	5.0	4						
③ 425	80	84	6.6	4.75	—						

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder
①	TICKET - 2537755				E/CURB PAL LINWOOD + CLEMENTS	
②	TICKET - 2537983				E/SIDEWALK + ADA ON LINWOOD + CLEMENTS	
③	TICKET - 2538080				E/SIDEWALK + ADA ON LINWOOD + PASADENA	

COMMENTS

*** SAMPLE FROM TRUCK CHUTE**

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS
(Use back if necessary)

72 TOTAL YARDS

MIX OR STREET TECHNICIAN

- ① MIX - P155FRQAO32 - 32 YD
- ② MIX - P155FRQAO32 - 40 YD
- ③ " " " " " "

DATE

G. Guzman 9-24-20

