

INSPECTOR'S REPORT OF CONCRETE PLACED - Roadway

FILE 210

CONTRACTOR		GENERAL NAME OF PROJECT <u>VARIOUS PROJECTS</u>	
SUBCONTRACTOR <u>MERLO CONSTRUCTION</u>		CONTROL SECTION ID - JOB NUMBER	
CONCRETE SUPPLIER <u>SUPERIOR MATERIALS</u>		ROUTE <u>BAGLEY - TRUMBULL + 24TH</u>	
MAXIMUM TIME <u>90 MIN</u>		STRUCTURE NUMBER <u>NORTH CURB SIDEWALK + ADA</u>	
WEATHER <u>CL</u> <u>48</u> A.M. <u>SUNNY</u> <u>70</u> P.M.		REPORT NUMBER <u>1872</u>	DATE <u>9.22.20</u>
MAX. WATER ADDED PER CYD GALLONS		REASON:	
BEAMS/CYLINDERS MADE (Sta, Time, #, etc.)		CURING COMPND. USED GALLONS	

Intended Air 5.5 % to 8.5 % TEMPERATURES - AIR - SLUMP Intended Slump 0-3" to 0-5" 2#3

TIME	ATMOSPHERE	CONCRETE	*AIR CONTENT %	SLUMP	CYLINDERS/ BEAMS	TIME	ATMOSPHERE	CONCRETE	*AIR CONTENTS %	SLUMP	CYLINDERS/ BEAMS
① 8:15	48	74	7.0	2.5	4	4:30	75	79	6.6	3.0	— (4)
② 10:35	61	74	7.4	4.5	4						
③ 11:5	70	78	6.8	5.0	—						

LOT #	LOT SIZE	SUBLOT #	SUBLOT SIZE	RANDOM #	QA Cylinder ID	Discrepancy Cylinder
①	TICKET-2536491				H/CURB BAGLEY + 17TH STREET	
②	TICKET-2536618				N/SIDEWALK + ADA BAGLEY + 10TH STREET	
③	TICKET-2536758				N/SIDEWALK + ADA BAGLEY + VERMONT	
④	TICKET-2536909				S/CURB FOR BUS STOP BAGLEY + WADASH	
COMMENTS <u>SAMPLE FROM TRUCK CHUTE</u>						

ITEM OR CODE NO.	STA. TO STA.	GRADE OF CONC.	LENGTH	WIDTH	DEPTH	MEASURED SQ. OR CU. YARDS	CYDS. PLAN	CYDS. USED	CYDS. WASTE	OVER UNDER %

REMARKS OR COMPUTATIONS
(Use back if necessary)

① - MIX - P155E7CQA032 - 14 YDS

② - MIX - P155E7CQA032 - 40 YDS

③ - " " " "

MIX OR STREET TECHNICIAN G. GUZMAN DATE 9.22.20

AW 9/22/20

cti