

BARNSCO

7800 Dix Street
Detroit, Michigan 48209
PH: 877-227-6786 FAX: 313-335-3121

Contract ID:Project #: 82000-205935 Date of Shipment: 10/24/2019
Contractor: MERLO Shipper/Invoice # 19900/4113

RECERTIFICATION

We certify that the following described material meets the specification requirements of the MICHIGAN DEPARTMENT OF TRANSPORTATION for the above project and this material is certified by the manufacturers indicated below

MATERIAL NAME, MDOT/Industry:	FIBER CUT 1/2" X 4" X 5'
MDOT SPEC #	914.03
MANUFACTURER	WR MEADOWS
LOT, HEAT OR IDENTIFICATION	9HJ203
QUANTITY:	960 PIECES

MATERIAL NAME, MDOT/Industry:	FIBER CUT 1/2" X 6" X 5'
MDOT SPEC #	914.03
MANUFACTURER	WR MEADOWS
LOT, HEAT OR IDENTIFICATION	9HJ207
QUANTITY:	640

MATERIAL NAME, MDOT/Industry:	
MDOT SPEC #	
MANUFACTURER	
LOT, HEAT OR IDENTIFICATION	
QUANTITY:	

MATERIAL NAME, MDOT/Industry:	
MDOT SPEC #	
MANUFACTURER	
LOT, HEAT OR IDENTIFICATION	
QUANTITY:	

MATERIAL NAME, MDOT/Industry:	
MDOT SPEC #	
MANUFACTURER	
LOT, HEAT OR IDENTIFICATION	
QUANTITY:	

All steel furnished on this certification is of domestic origin and is in compliance with the project "Buy America" provision & all processes performed within the United States

Signed: Jessica Steward TITLE: Highway Department

W. R. MEADOWS, INC.

P.O. BOX 338 • HAMPSHIRE, IL 60140-0338
www.wrmeadows.com • wrmit@wrmeadows.com



A Family Company Since 1926

TELEPHONE: 847-214-2100
800-825-5978
FAX: 847-683-4544

August 22, 2019

Barnsco
7800 Dix ST.
Detroit, MI 48209

Reference: P.O. # 563 SO# 100025887


To Whom It May Concern:

W.R. MEADOWS certifies that the following are Test Results for W.R. MEADOWS FIBRE EXPANSION JOINT:

	960 PCS 1/2"x4"x5'	720 PCS 1/2"x5-1/2"x5'	640 PCS 1/2"x6"x5'
Lot Number:	9HJ203	9HJ204	9HJ207
Resistance to handling:	Good	Good	Good
Compression (to 50% of original thickness), psi:	400	400	400
Extrusion, inches:	0.10	0.10	0.10
Recovery, %:	79	79	79
Density, pounds/cubic foot:	23.1	23.3	23.6
Water absorption, %:	8.6	8.1	8.3
Asphalt content, %:	37.1	37.1	37.8
Voc Content, g/l:	0	0	0
Weathering tests:	Pass	Pass	Pass

As indicated by the foregoing test results, FIBRE EXPANSION JOINT complies with the laboratory test requirements of ASTM D1751, Federal Specification HH-F-341 F, Type I, and AASHTO M 213.

Should field sampling and/or field or laboratory work be required, W. R. MEADOWS, INC. cannot be held responsible for any cost incurred if this product is used prior to receipt of that approval.



Steven Geiger
Technical Services Manager,
Restoration/Building Envelopment

Subscribed and sworn to before me
this 22nd day of August 2019.

Notary Public