



CONSTRUCTION CONSULTING & TESTING, INC.

TOLEDO OFFICE - 700 S. River Rd. Waterville, Ohio 43566 Ph.: (419) 878-7304
DETROIT OFFICE - 35410 Mound Rd. Sterling Hts., Michigan 48310 Ph.: (586) 795-2877

Client: Fort Wayne Contracting
300 E. Seven Mile
Detroit, MI 48203

Project: PW 7018

Date: August 12, 2021

CCT No.: 201-20037-19

Page: 1 of 2

REPORT OF SERVICES

As requested, a representative of CCT reported to the above referenced project to perform concrete QA/QC Testing. Results are attached.

<u>Mix ID</u>	<u>Item Description</u>	<u>Concrete Placed</u>	<u>Plan Quantity</u>
P-NCOM	Structures Adjustments	14.0 yd³	

Technician J. Richardson	Project Time 10:30 AM - 12:00 PM	Mileage
-----------------------------	-------------------------------------	---------

Field Notes:

[illegible]

Attachments: Concrete Field Report

Distribution: FWC

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: PW 7018				Mix Type: P-NCOM			Theo. Unit Weight:			Air Spec.: 5.5% - 8.5%		
Contractor: Fort Wayne Contracting				Mix ID:			Theo. Yield:			Slump Spec.: 6" Max		
Consultant: CCT				Lot No.:			Supplier: SRM			Temp. Spce.: 90° Max		
Tester: J. Richardson				Lot Size:			Plant: Detroit			Time Spec.: 60 Max		
Signature:				Date: August 12, 2021								

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Yield
QC-1	82007471	7/7	4	10:34 AM	12:00 PM	6.4	5	84	77	---	---

General Location: Structures Adjustments

Test No.	Cylinder ID	Location:
QC-1	Set 1	Scotten & Fisher Fwy W

Total Placed:	14.0 yd ³
---------------	----------------------

Comments:

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566
Ph: 419-878-7304 Fax: 419-878-7305

Client: Fort Wayne Contracting
300 E. Seven Mile
Detroit, MI 48203

Date: 8/12/2021
CCT No.: 201-20037-19
Page: 2 of 2