



CONSTRUCTION CONSULTING & TESTING, INC.

TOLEDO OFFICE - 700 S. River Rd. Waterville, Ohio 43566 Ph.: (419) 878-7304
DETROIT OFFICE - 35410 Mound Rd. Sterling Hts., Michigan 48310 Ph.: (586) 795-2877

Client: Fort Wayne Contracting
300 E. Seven Mile
Detroit, MI 48203

Project: PW 7023

Date: November 9, 2020

CCT No.: 201-20085-3

Page: 1 of 2

REPORT OF SERVICES

As requested, a representative of CCT reported to the above referenced project to perform concrete QA/QC Testing. Results are attached.

<u>Mix ID</u>	<u>Item Description</u>	<u>Concrete Placed</u>	<u>Plan Quantity</u>
P-NCOM	Structure Repair	27.0 yd ³	

Technician R. McQueen	Project Time 1:30 PM - 5:30 PM	Mileage
--------------------------	-----------------------------------	---------

Field Notes:

Attachments: Concrete Field Report

Distribution: FWC

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: PW 7023				Mix Type: PNC			Theo. Unit Weight:		Air Spec.: 5.5 - 8.5		
Contractor: Fort Wayne Contracting				Mix ID: P-NCOM			Theo. Yield:		Slump Spec.: 6" Max		
Consultant: CCT				Lot No.:			Supplier: SRM		Temp. Spce.: 90° Max		
Tester: R. McQueen				Lot Size:			Plant: 14		Time Spec.: 60 Max		
Signature:				Date: November 9, 2020							

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Yield
QC-1	818108	9/9	4	2:14 PM	3:14 PM	5.6	4 1/2	67	70	---	---
QC-2	818121	9/18	---	3:42 PM	4:40 PM	6.0	4 3/4	66	71	---	---

General Location: Structure Repair

Test No.	Cylinder ID	Location:
QC-1	Set 1	Conner NB Lane 3 North of Jefferson

Total Placed:	27.0 yd ³
---------------	----------------------

Comments:

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566
Ph: 419-878-7304 Fax: 419-878-7305

Client: Fort Wayne Contracting
300 E. Seven Mile
Detroit, MI 48203

Date: 11/9/2020
CCT No.: 201-20085-3
Page: 2 of 2