



CONSTRUCTION CONSULTING & TESTING, INC.

TOLEDO OFFICE - 700 S. River Rd. Waterville, Ohio 43566 Ph.: (419) 878-7304
DETROIT OFFICE - 35410 Mound Rd. Sterling Hts., Michigan 48310 Ph.: (586) 795-2877

Client: Century Cement
12670 Sibley Road
Riverview, MI 48193

Project: PW 7023

Date: June 24, 2021

CCT No.: 201-20086-2

Page: 1 of 2

REPORT OF SERVICES

As requested, a representative of CCT reported to the above referenced project to perform concrete QA/QC Testing. Results are attached.

<u>Mix ID</u>	<u>Item Description</u>	<u>Concrete Placed</u>	<u>Plan Quantity</u>
P1-DETM-1	Pavement	110.0 yd³	

Technician R. McQueen	Project Time 6:30 AM - 5:30 PM	Mileage
--------------------------	-----------------------------------	---------

Field Notes:

[illegible]

Attachments: Concrete Field Report

Distribution: Century Cement

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: PW 7023				Mix Type: P1			Theo. Unit Weight:			Air Spec.: 5.5 - 8.5%		
Contractor: Century Cement				Mix ID: P1-DETM-1			Theo. Yield:			Slump Spec.: 6" Max		
Consultant: CCT				Lot No.:			Supplier: Hercules			Temp. Spce.: 90° Max		
Tester: R. McQueen				Lot Size:			Plant: 4			Time Spec.: 60 Max		
Signature:				Date: June 24, 2021								

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Street
QC-1	422986	11/11	4	6:29 AM	7:39 AM	5.6	4 3/4	76	68	---	---
QC-2	422993	11/22	---	7:33 AM	8:51 AM	5.1/6.4	4 1/2	77	70	---	---
QC-3	423000	11/33	---	8:20 AM	9:45 AM	5.0/6.0	4 3/4	76	72	---	---
QC-4	423009	11/44	---	9:27 AM	10:41 AM	5.9	5 3/4	75	75	---	---
QC-5	423019	11/55	4	10:52 AM	12:00 PM	5.7	5	82	77	---	---
QC-6	423029	11/66	---	12:21 PM	1:26 PM	5.7	4 3/4	82	80	---	---
QC-7	423039	11/88	---	1:32 PM	2:50 PM	7.0	5 1/2	84	82	---	---
QC-8	423049	11/99	4	2:38 PM	4:05 PM	7.6	5 1/4	85	83	---	---
QC-9	423059	11/110	---	3:42 PM	4:55 PM	6.1	4 3/4	83	82	---	---

General Location: Pavement

Test No.	Cylinder ID	Location:
QC-1	Set 1	NB Conner @ Chandler Park
QC-5	Set 2	NB Conner @ Chandler Park
QC-8	Set 3	NB Conner @ Kercheval

Total Placed:	110.0 yd ³
---------------	-----------------------

Comments: 	Client: Century Cement 12670 Sibley Road Riverview, MI 48193
---	---

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566 Ph: 419-878-7304 Fax: 419-878-7305	Date: 6/24/2021 CCT No.: 201-20086-2 Page: 2 of 2
--	--