



CONSTRUCTION CONSULTING & TESTING, INC.

TOLEDO OFFICE - 700 S. River Rd. Waterville, Ohio 43566 Ph.: (419) 878-7304
DETROIT OFFICE - 35410 Mound Rd. Sterling Hts., Michigan 48310 Ph.: (586) 795-2877

Client: Century Cement
12670 Sibley Road
Riverview, MI 48193

Project: PW 7023

Date: June 29, 2021

CCT No.: 201-20086-3

Page: 1 of 2

REPORT OF SERVICES

As requested, a representative of CCT reported to the above referenced project to perform concrete QA/QC Testing. Results are attached.

<u>Mix ID</u>	<u>Item Description</u>	<u>Concrete Placed</u>	<u>Plan Quantity</u>
P1-DETM-1	Pavement	28.0 yd³	

Technician R. McQueen	Project Time 6:30 AM - 12:15 PM	Mileage
--------------------------	------------------------------------	---------

Field Notes:

[illegible]

Attachments: Concrete Field Report

Distribution: Century Cement

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: PW 7023				Mix Type: P1			Theo. Unit Weight:		Air Spec.: 5.5 - 8.5%		
Contractor: Century Cement				Mix ID: P1-DETM-1			Theo. Yield:		Slump Spec.: 6" Max		
Consultant: CCT				Lot No.:			Supplier: Hercules		Temp. Spce.: 90° Max		
Tester: R. McQueen				Lot Size:			Plant: 4		Time Spec.: 60 Max		
Signature:				Date: June 29, 2021							

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Street
QC-1	423178	11/11	4	6:23 AM	7:40 AM	6.9	4 1/4	86	74	---	---
QC-2	423189	11/22	---	7:23 AM	8:40 AM	8.0	5 1/4	86	78	---	---
QC-3	423195	11/28	---	8:35 AM	9:50 AM	7.7	5	89	80	---	---
QC-4	423206	11/11	Rejected	10:17 AM	---	---	---	93	86	---	---
QC-5	423212	11/22	Rejected	10:52 AM	---	---	---	93	86	---	---

General Location: Pavement

Test No.	Cylinder ID	Location:
QC-1	Set 1	Conner & Kercheval, NE corner

Total Placed: 28.0 yd³

Comments: QC-4 rejected, 93F, retarder added
 QC-4 rejected, 93F

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566
Ph: 419-878-7304 Fax: 419-878-7305

Client: Century Cement
 12670 Sibley Road
 Riverview, MI 48193

Date: 6/29/2021
CCT No.: 201-20086-3
Page: 2 of 2