



CONSTRUCTION CONSULTING & TESTING, INC.

TOLEDO OFFICE - 700 S. River Rd. Waterville, Ohio 43566 Ph.: (419) 878-7304
DETROIT OFFICE - 35410 Mound Rd. Sterling Hts., Michigan 48310 Ph.: (586) 795-2877

Client: Century Cement
12670 Sibley Road
Riverview, MI 48193

Project: PW 7023

Date: June 30, 2021

CCT No.: 201-20086-4

Page: 1 of 2

REPORT OF SERVICES

As requested, a representative of CCT reported to the above referenced project to perform concrete QA/QC Testing. Results are attached.

<u>Mix ID</u>	<u>Item Description</u>	<u>Concrete Placed</u>	<u>Plan Quantity</u>
P1-DETMR-1	Pavement	121.0 yd³	

Technician R. McQueen	Project Time 5:30 AM - 4:45 PM	Mileage
--------------------------	-----------------------------------	---------

Field Notes:

[illegible]

Attachments: Concrete Field Report

Distribution: Century Cement

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: PW 7023				Mix Type: P1			Theo. Unit Weight:			Air Spec.: 5.5 - 8.5%		
Contractor: Century Cement				Mix ID: P1-DETM-1			Theo. Yield:			Slump Spec.: 6" Max		
Consultant: CCT				Lot No.:			Supplier: Hercules			Temp. Spce.: 90° Max		
Tester: R. McQueen				Lot Size:			Plant: 4			Time Spec.: 60 Max		
Signature:				Date: June 30, 2021								

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Street
QC-1	423228	11/11	4	5:13 AM	6:45 AM	6.9	5 1/2	85	75	---	---
QC-2	423243	11/33	---	7:49 AM	8:45 AM	8.0	5 1/4	81	75	---	---
QC-3	423257	11/55	4	10:57 AM	12:00 PM	6.7	4 1/2	84	76	---	---
QC-4	423270	11/77	---	12:12 PM	1:20 PM	7.3	5 1/4	86	79	---	---
QC-5	423280	11/99	---	1:34 PM	3:14 PM	7.3	5	85	81	---	---
QC-6	423289	11/121	2	3:22 PM	4:20 PM	8.0	5 1/4	86	82	---	---

General Location: Pavement

Test No.	Cylinder ID	Location:
QC-1	Set 1	NB Conner @ Vernor on sidewalk
QC-3	Set 2	NB Conner south of Chandler Park
QC-6	Set 3	NB Conner south of Chandler Park

Total Placed:	121.0 yd ³
---------------	-----------------------

Comments: 	Client: Century Cement 12670 Sibley Road Riverview, MI 48193
---	---

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566 Ph: 419-878-7304 Fax: 419-878-7305	Date: 6/30/2021 CCT No.: 201-20086-4 Page: 2 of 2
--	--