



CONSTRUCTION CONSULTING & TESTING, INC.

TOLEDO OFFICE - 700 S. River Rd. Waterville, Ohio 43566 Ph.: (419) 878-7304
DETROIT OFFICE - 35410 Mound Rd. Sterling Hts., Michigan 48310 Ph.: (586) 795-2877

Client: Century Cement
12670 Sibley Road
Riverview, MI 48193

Project: PW 7023

Date: July 2, 2021

CCT No.: 201-20086-5

Page: 1 of 2

REPORT OF SERVICES

As requested, a representative of CCT reported to the above referenced project to perform concrete QA/QC Testing. Results are attached.

<u>Mix ID</u>	<u>Item Description</u>	<u>Concrete Placed</u>	<u>Plan Quantity</u>
P1-DETM-2	Pavement	93.0 yd³	

Technician R. McQueen	Project Time 6:30 AM - 4:15 PM	Mileage
--------------------------	-----------------------------------	---------

Field Notes:

[illegible]

Attachments: Concrete Field Report

Distribution: Century Cement

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: PW 7023				Mix Type: P1			Theo. Unit Weight:			Air Spec.: 5.5 - 8.5%		
Contractor: Century Cement				Mix ID: P1-DETM-2			Theo. Yield:			Slump Spec.: 6" Max		
Consultant: CCT				Lot No.:			Supplier: Hercules			Temp. Spce.: 90° Max		
Tester: R. McQueen				Lot Size:			Plant: 1/4			Time Spec.: 60 Max		
Signature:				Date: July 2, 2021								

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Street
QC-1	125635	11/11	4	8:40 AM	9:55 AM	5.3/5.8	5 3/4	74	65	---	---
QC-2	423429	11/22	---	9:33 AM	10:50 AM	5.5	5	75	66	---	---
QC-3	423437	6/28	---	10:36 AM	12:05 PM	7.0	4 1/2	80	69	---	---
QC-4	423449	10/38	---	12:11 PM	1:20 PM	5.8	4 1/4	77	73	---	---
QC-5	423463	11/60	4	1:11 PM	2:25 PM	6.0	5 1/4	80	73	---	---
QC-6	423472	11/82	---	2:30 PM	3:25 PM	5.8	4 3/4	82	75	---	---

General Location: Pavement

Test No.	Cylinder ID	Location:
QC-1	Set 1	NB Conner @ north of Vernor
QC-5	Set 2	NB Conner @ south of Chandler Park

Total Placed: 93.0 yd³

Comments: QC-1: Air low, AEA added on site

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566
Ph: 419-878-7304 Fax: 419-878-7305

Client: Century Cement
12670 Sibley Road
Riverview, MI 48193

Date: 7/2/2021
CCT No.: 201-20086-5
Page: 2 of 2