



CONSTRUCTION CONSULTING & TESTING, INC.

TOLEDO OFFICE - 700 S. River Rd. Waterville, Ohio 43566 Ph.: (419) 878-7304
DETROIT OFFICE - 35410 Mound Rd. Sterling Hts., Michigan 48310 Ph.: (586) 795-2877

Client: Century Cement
12670 Sibley Road
Riverview, MI 48193

Project: PW 7023

Date: July 8, 2021

CCT No.: 201-20086-7

Page: 1 of 2

REPORT OF SERVICES

As requested, a representative of CCT reported to the above referenced project to perform concrete QA/QC Testing. Results are attached.

<u>Mix ID</u>	<u>Item Description</u>	<u>Concrete Placed</u>	<u>Plan Quantity</u>
P1-DETMR-1	Pavement	10.0 yd³	

Technician R. McQueen	Project Time 11:30 AM - 3:15 PM	Mileage
--------------------------	------------------------------------	---------

Field Notes:

[illegible]

Attachments: Concrete Field Report

Distribution: Century Cement

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: PW 7023				Mix Type: P1			Theo. Unit Weight:		Air Spec.: 5.5 - 8.5%		
Contractor: Century Cement				Mix ID: P1-DETM-1			Theo. Yield:		Slump Spec.: 6" Max		
Consultant: CCT				Lot No.:			Supplier: Hercules		Temp. Spce.: 90° Max		
Tester: R. McQueen				Lot Size:			Plant: 4		Time Spec.: 60 Max		
Signature:				Date: July 8, 2021							

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Street
QC-1	423690	11/11	---	11:23 AM	---	*9.0/9.0	4 1/2	81	73	---	---
QC-2	423695	10/10	4	12:38 PM	1:55 PM	6.9	3 3/4	82	74	---	---
QC-3	923200	11/21	---	1:22 PM	---	*9.0	4 1/2	86	75	---	---

General Location: Pavement

Test No.	Cylinder ID	Location:
QC-2	Set 1	NB Conner, south of Chandler Park

Total Placed: 10.0 yd³

Comments: *QC-1: Air high, rejected
 *QC-3: Air high, rejected

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566
Ph: 419-878-7304 Fax: 419-878-7305

Client: Century Cement
 12670 Sibley Road
 Riverview, MI 48193

Date: 7/8/2021
CCT No.: 201-20086-7
Page: 2 of 2