



CONSTRUCTION CONSULTING & TESTING, INC.

TOLEDO OFFICE - 700 S. River Rd. Waterville, Ohio 43566 Ph.: (419) 878-7304
DETROIT OFFICE - 35410 Mound Rd. Sterling Hts., Michigan 48310 Ph.: (586) 795-2877

Client: Century Cement
12670 Sibley Road
Riverview, MI 48193

Project: PW 7023

Date: July 12, 2021

CCT No.: 201-20086-9

Page: 1 of 2

REPORT OF SERVICES

As requested, a representative of CCT reported to the above referenced project to perform concrete QA/QC Testing. Results are attached.

<u>Mix ID</u>	<u>Item Description</u>	<u>Concrete Placed</u>	<u>Plan Quantity</u>
P1-DETM-1	Pavement	78.0 yd ³	

Technician R. McQueen	Project Time 6:30 AM - 4:00 PM	Mileage
--------------------------	-----------------------------------	---------

Field Notes:

Attachments: Concrete Field Report

Distribution: Century Cement

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: PW 7023				Mix Type: P1			Theo. Unit Weight:			Air Spec.: 5.5 - 8.5%		
Contractor: Century Cement				Mix ID: P1-DETM-1			Theo. Yield:			Slump Spec.: 6" Max		
Consultant: CCT				Lot No.:			Supplier: Hercules			Temp. Spce.: 90° Max		
Tester: R. McQueen				Lot Size:			Plant: 4			Time Spec.: 60 Max		
Signature:				Date: July 12, 2021								

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Street
QC-1	423847	11/11	4	6:23 AM	7:50 AM	6.7	5 1/4	81	68	---	---
QC-2	423880	7/34	---	9:27 AM	11:15 AM	6.5	5	77	67	---	---
QC-3	423909	11/45	---	11:41 AM	12:50 PM	7.2	5 1/2	81	68	---	---
QC-4	423929	11/67	4	1:17 PM	2:35 PM	7.1	5	82	70	---	---
QC-5	423941	11/78	---	2:24 PM	3:40 PM	6.5	4 3/4	80	70	---	---

General Location: Sidewalk

Test No.	Cylinder ID	Location:
QC-1	Set 1	NB Conner @ south of Mack
QC-4	Set 2	NB Conner @ south of Frankfort

Total Placed:	78.0 yd ³
---------------	----------------------

Comments: _____

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566
Ph: 419-878-7304 Fax: 419-878-7305

Client: Century Cement
12670 Sibley Road
Riverview, MI 48193

Date: 7/12/2021
CCT No.: 201-20086-9
Page: 2 of 2