



CONSTRUCTION CONSULTING & TESTING, INC.

TOLEDO OFFICE - 430 Bishop Rd. Ste A Bowling Green, Ohio 43402 Ph.: (419) 878-7304

DETROIT OFFICE - 35410 Mound Rd. Sterling Hts., Michigan 48310 Ph.: (586) 795-2877

Client: Century Cement
12670 Sibley Road
Riverview, MI 48193

Project: Conner

Date: May 23, 2022

CCT No.: 201-22037-2

Page: 1 of 2

REPORT OF SERVICES

As requested, a representative of CCT reported to the above referenced project to perform concrete QA/QC Testing. Results are attached.

<u>Mix ID</u>	<u>Item Description</u>	<u>Concrete Placed</u>	<u>Plan Quantity</u>
P1-DETM	Sidewalk	22.0 yd³	

Technician R. Diaz	Project Time 3:15 PM - 7:00 PM	Mileage
-----------------------	-----------------------------------	---------

Field Notes:

[illegible]

Attachments: Concrete Field Report

Distribution: Century Cement

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: Conner				Mix Type:			Theo. Unit Weight:			Air Spec.: 5.5 - 8.5%		
Contractor: Century Cement				Mix ID: P1-DETM			Theo. Yield:			Slump Spec.: 6" Max		
Consultant: CCT				Lot No.:			Supplier: Hercules			Temp. Spce.: 90° Max		
Tester: R. Diaz				Lot Size:			Plant: 1			Time Spec.: 90 Max		
Signature:				Date: May 23, 2022								

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Street
QC-1	136447	11/11	2	4:02 PM	6:00 PM	6.4	5	70	59	---	---

General Location: Sidewalk

Test No.	Cylinder ID	Location:
QC-1	Set 1	NB Conner & Chandler Pk

Total Placed:	22.0 yd ³
---------------	----------------------

Comments:

Construction Consulting & Testing, Inc. 430 Bishop Rd. Ste A Bowling Green, Ohio 43402
Ph: 419-878-7304 Fax: 41-664-4543

Client: Century Cement
 12670 Sibley Road
 Riverview, MI 48193

Date: 5/23/2022
CCT No.: 201-22037-2
Page: 2 of 2