CONCRETE FIELD QA/QC INSPECTION REPORT

Project:	Conner	Mix Type:	PNC	Theo. Unit Weight:		Air Spec.:	5.5-8.0
Contractor:	Cutting W	Mix ID:		Theo. Yield:		Slump Spec.:	6in Max
Consultant:		Lot No.:		Supplier:	SKM Concrete	Temp. Spec.:	90
Tester:	Ramiro P.	Sublot No.:		Plant:	14	Time Spec.:	60 min
Signature:		Date:	11/14				

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Yield
1	916461	9/9	2 Beams	11:07	11:55	7.0	5	62	41		

General Location: Pavement Repair

Test No.	Cylinder ID	Location:
		Conner & Clarkeview St
1		

Total Volume: 30 yd

Comments:

Client: CCH

Date: 11/14

CCT No.:

Page:

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566
Ph: 419-878-7304 Fax: 419-878-7305

Scanned with CamScanner