CONCRETE FIELD QA/QC INSPECTION REPORT

Project:	Conner Ave	Mix Type:	P1	Theo. Unit Weight:		Air Spec.:	5.5-8.0
Contractor:	CCT/HVV	Mix ID:	P1-DSTM	Theo. Yield:		Slump Spec.:	6in MPX
Consultant:		Lot No.:		Supplier:	SRM Concrete	Temp. Spce.:	90
Tester:	Ramiro D	Sublot No.:		Plant:	14	Time Spec.:	60 min
Signature:	RD	Date:	11/14				

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Yield
1	818429	11/11	4	640A	900A	5.6	5	56	28		
								62			

General Location: Sidewalk Repair

Test No.	Cylinder ID	Location:
1	Set 1	Conner and Jefferson E.

Total Volume: 33

Comments:

Client: CCT

Construction Consulting & Testing, Inc. P. O. Box 287 Waterville, Ohio 43566
Ph: 419-878-7304 Fax: 419-878-7305

Date: 11/14
CCT No.:
Page:

Scanned with CamScanner