



Somat Engineering, Inc.

26445 Northline Rd, Taylor, MI 48180
Tel: 734-946-4966 Fax: 734-946-1147

ASTM D2950

REPORT NUMBER: 202 SHEET: 3 OF 3

ASPHALT DENSITY DETERMINATION REPORT

DATE: 11/3/2020

JOB NUMBER: 2019057D-002 (PW-7023)

PROJECT NAME: Conner Improvements

LOCATION: Detroit, MI

GAUGE NUMBER: 2127

CLIENT: AECOM

OWNER: City of Detroit

CONTRACTOR: Ajax

PROJECT ENGINEER: Alan Ostrowski, P.E.

WEATHER: Sunny

TEST PERFORMED ON:		WEARING COURSE (WC)		LEVELING COURSE (LC)		X		BASE COURSE (BC)		OTHER			
STRUCTURE: Mainline													
TEST			WET DENSITY		MOISTURE			DENSITY		TEST LOCATION			
ORIG.	RETEST	DEPTH	DENSITY COUNTS	WET DENSITY	MOIST. COUNTS	MOIST.	MOIST.	MAX DENSITY	COMPACT.	STATIONING/LOCATION	OFFSET OF CL (FT)		COURSE
		INCH	DC	PCF	MC	PCF	%	PCF	%		LEFT	RIGHT	
23		BS	737	146.6	72	9.4	6.8	158.1	92.7	42.3802, -82.9655	7		BC
24		BS	747	145.6	64	8.2	6	158.1	92.1	42.3792, -82.9649	6		BC
25		BS	748	145.5	58	7.4	5.3	158.1	92	42.3834, -82.9676	14		BC
26		BS	746	145.7	54	6.8	4.9	158.1	92.2	42.3823, -82.9669	19		BC
27		BS	744	145.9	52	6.5	4.7	158.1	92.3	42.3813, -82.9662	22		BC
28		BS	730	147.3	57	7.2	5.2	158.1	93.2	42.3802, -82.9655	18		BC
MAXIMUM DETERMINATION (LAB)										PRESCALE			
NOTE: Gmb to Marshall conversion is $Gmb * 62.4 (PCF) = MARSHALL (PCF)$										16			
NOTE: Gmm to TMD conversion is $Gmm * 62.4 (PCF) = TMD (PCF)$										16			
MAXIMUM WET DENSITY BY:			MARSHALL/Gmb 95.0%			TMD/Gmm 92.0% - 96.0%			DENSITY		MOISTURE		
			TMD/Gmm 92.0% - 97.0%			X TMD/Gmm 92.0% - 98.0%			READING 1		2761 419		
REMARKS:										READING 2		2745 417	
										READING 3		2766 414	
										READING 4		2766 417	
										OPERATING STANDARDS (READING 5)			
										DENSITY		MOISTURE	
		2766 418											
SOMAT FIELD REPRESENTATIVE: Ryan Castillo										DATE: 11/3/2020			
SOMAT PROJECT MANAGER(s): Steve Drummond, P.E.										DATE: 11/4/2020			

*All results noted in this report relate only to items inspected or tested by Somat Engineering, Inc. and/or Somat Engineering of Ohio, Inc. (Somat). This report shall not be reproduced, except in full, without the prior written approval of Somat.