

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231889 DATE: 08/03/20		
DRIVER INSTRUCTION: GALLAGHER & CARPENTER // WEST OF CONANT // SOUTH OF DAVISON !!!! 1 INCH !!!!							MAP PAGE: DT4273C2		TIME: 8:40	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:		
	107	MIKE CAPLING	4831	30.01	10.00	1.00 in	6.50	1		
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:		
P1-SSFW		10.00	yd	MDOT P1 S35 SLIP FORM WRA						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.										
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.					
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT	DETROIT	M-11						
FLY ASH:										
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	71-003	COMPANY REPRESENTATIVE (signature) <i>Kelley J. [Signature]</i> X		COLLECTED (circle one) CHECK CASH CREDIT				
INTERM AGG:										
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003							
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐						
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X				
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.										
UNLOAD PROMPTLY: Excess time will be charged to the buyer.										

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4831	MICAPLING	user1	1231889	1231889	8:40	8/3/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SSFW				W2	319786

Material	Design Qty	Required	Batched	% Var	Moisture	Actual	Wat
L6AA-PIN	1680 lb	16800 lb	16800 lb	0.00%			
2NS-SMR	1490 lb	15645 lb	15620 lb	-0.16%	5.00% M	89 gl	
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	26.5 gl	150.7 gl	151.0 gl	0.18%		151.0 gl	
OAE-BA	5 oz	316 oz	316 oz	0.13%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	38970 lb	Design W/C: 0.420	Water/Cement: 0.420 T	Design	265.0 gl	Actual	240.1 gl To Add: 24.9 gl
Slump:	1.00 in	# Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	-2.5 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231918 DATE: 08/03/20	
DRIVER INSTRUCTION: GALLAGHER & CARPENTER // WEST OF CONANT // SOUTH OF DAVISION !!!! 1 INCH !!!!							MAP PAGE: DT4273C2	TIME: 11:05	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	107	MIKE CAPLING	4831	30.01	20.00	1.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SSFW		10.00	yd	MDOT P1 S35 SLIP FORM WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)				
INTERM AGG:					<i>Kelley J. [Signature]</i>				
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one)				
					X				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
4831	MICAPLING	user1	1231918	1231918	11:05 8/3/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SSFW				W2	319815

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1680 lb	16800 lb	16800 lb	0.00%			
2NS-SMR	1490 lb	15496 lb	15500 lb	0.03%	4.00% M	71 gl	
CMT1-LAA	342 lb	3420 lb	3430 lb	0.29%			
CMGS-CRHS	184 lb	1840 lb	1850 lb	0.54%			
WAT1	26.5 gl	178.6 gl	179.0 gl	0.24%		179.0 gl	
0AE-BA	5 oz	316 oz	315 oz	-0.19%			
0WRA-PR	16 oz	158 oz	157 oz	-0.51%			
HWATER	% #	gl	gl				

Actual Load	39103 lb	Design W/C:	0.420	Water/Cement:	0.419 T	Design	265.0 gl	Actual	250.4 gl	To Add:	14.6 gl
Slump:	1.00 in	#	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.5 gl / yd			

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231940 DATE: 08/03/20	
DRIVER INSTRUCTION: CARPENTER // WEST OF CONANT // SOUTH OF DAVISION !!!! 1 INCH !!!!							MAP PAGE: DT4273C2	TIME: 13:29	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	107	WAYNE JOHNSON	4832	30.01	30.00	1.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SSFW		10.00	yd	MDOT P1 S35 SLIP FORM WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)				
INTERM AGG:					<i>Kelegh J. Johnson</i>				
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	X				
					COLLECTED (circle one)				
					CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
4832	WAJOHNSON	user1		1231940	1231940	13:29	8/3/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
10.00 yd	P1-SSFW				W2	319837	

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1680 lb	16800 lb	16820 lb	0.12%			
2NS-SMR	1490 lb	15496 lb	15440 lb	-0.36%	4.00% M	71 gl	
CMT1-LAA	342 lb	3420 lb	3430 lb	0.29%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	26.5 gl	178.6 gl	179.0 gl	0.24%		179.0 gl	
0AE-BA	5 oz	316 oz	316 oz	-0.03%			
0WRA-PR	16 oz	158 oz	158 oz	0.13%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	39053 lb	Design W/C: 0.420	Water/Cement: 0.420	T	Design	265.0 gl	Actual 250.2 gl To Add: 14.8 gl
Slump:	1.00 in	# Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	-1.5 gl / yd	



DRISENGA & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>8-3-20</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>Jackie Richards</u>	# <u>01362857</u>
CONTRACTOR: <u>Westside</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McCoy's - 7mi Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>7:20 Partly Cloudy</u> P.M.	TIME ARRIVED: <u>8:30</u> SCHEDULED ARRIVAL TIME: <u>9:00</u> TIME LEFT SITE: <u>9:50</u>	
AGGREGATE CORRECTION FACTOR: <u>.2</u>		

Pour Description: Carpenter Run Joseph Mampau to
Conant

Mix Design: P1-SSFW Quantity Placed (yd³): 10.0 Lot Number: — Sublot: —
Grade of Concrete: P1 Batch Quantity (yd³): 10.0 Pour Start: 9:15 Pour End: 9:50

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4831	1231889	8:40	9:15	9:50	1 1/2"	75°	80°	6.2	140.4	1.027	GC1-4

REMARKS

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #4 @ 1405 CARPENTER @ CURBS				TICKET CODE: 1232059 DATE: 08/04/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OFF NORTHBOUND I-75 SERVICE DR NORTH OF CANIFF							MAP PAGE: DT4273B3	TIME: 15:44	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY ORDERED:	QTY DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	108	STEVE JOHNSON	2600	40.00	40.00	1.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SSFW		10.00	yd	MDOT P1 S35 SLIP FORM WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature)				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING HILL RECLAMATION		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AGE:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE _____			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2600	STJOHNSON	user1	1232059	1232059	15:44	8/4/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SSFW				W2	319956

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1880 lb	18800 lb	18800 lb	0.00%			
2NS-SMR	1490 lb	15422 lb	15360 lb	-0.40%	3.50% M	62 gl	
CMT1-LAA	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	26.5 gl	192.5 gl	192.0 gl	-0.28%		192.0 gl	
OAE-BA	5 oz	300 oz	300 oz	-0.11%			
OWRA-PR	18 oz	158 oz	158 oz	0.13%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	39041 lb	Design W/C:	0.420	Water/Cement:	0.421	T	
Slump:	1.00 in	#	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	
						Design	265.0 gl
						Actual	254.2 gl
						To Add:	10.8 gl
						Trim Water:	-1.0 gl / yd

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: 449792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 @ 1400 CARPENTER WB CURB				TICKET CODE: 1232040 DATE: 08/04/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OFF NORTHBOUND I-75 SERVICE DR NORTH OF CANIFF							MAP PAGE: DT4273A3	TIME: 13:30	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	108	GREG KROESCH	4834	30.01	30.00	1.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SSFW		10.00	yd	MDOT P1 S35 SLIP FORM WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature)				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	<i>Kelley J. Thompson</i> COLLECTED (circle one)				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
FINE AGG:					X	CHECK CASH CREDIT			
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4834	GRKROESCH	user1	1232040	1232040	13:30	8/4/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SSFW				W2	319937

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1680 lb	16800 lb	18820 lb	0.12%			
2NS-SMR	1490 lb	15422 lb	15400 lb	-0.14%	3.50% M	62 gl	
CMT1-LAA	342 lb	3420 lb	3430 lb	0.29%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	28.5 gl	182.5 gl	193.0 gl	0.26%		193.0 gl	
OAE-BA	5 oz	316 oz	316 oz	0.13%			
OWRA-PR	16 oz	158 oz	157 oz	-0.51%			
HWATER	% #	gl	gl				

Actual Load		39130 lb		Design W/C: 0.420		Water/Cement: 0.420 T		Design 285.0 gl		Actual 255.4 gl		To Add: 9.6 gl	
Slump:		1.00 in		#		Water in Truck: 0.0 gl		Adjust Water: 0.0 gl / Load		Trim Water: -1.0 gl / yd			

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2 @ 1130 / 1310</i> CARPENTER WB CORR				TICKET CODE: 1232018 DATE: 08/04/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OFF NORTHBOUND I-75 SERVICE DR NORTH OF CANIFF							MAP PAGE: DT4273A3	TIME: 11:02	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY ORDERED:	QTY DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	108	JOE CHAPP	2442	30.01	20.00	1.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SSFW		10.00	yd	MDOT P1 S35 SLIP FORM WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGBSF:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT	DETROIT	M-11					
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	71-003	COMPANY REPRESENTATIVE (signature) <i>Kelany Jankowski</i> X					
INTERM. AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003						
FINE AGG:				COLLECTED (circle one) CHECK CASH CREDIT					
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. <i>WESTSIDE CONCRETE</i> X			
LEAVE PLANT:	ARRIVE AT JOB:	START HOUR:	FINISH HOUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE <i>Kelany Jankowski</i>			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2442	JOCHAPP	user1	1232018	1232018	11:02	8/4/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SSFW				W2	319915

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1880 lb	16800 lb	16800 lb	0.00%			
2NS-SMR	1490 lb	15422 lb	15380 lb	-0.27%	3.50% M	62 gl	
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	28.5 gl	192.5 gl	192.0 gl	-0.26%		192.0 gl	
0AE-BA	5 oz	316 oz	316 oz	-0.03%			
0WRA-PR	16 oz	158 oz	158 oz	0.13%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	39072 lb	Design W/C: 0.420	Water/Cement: 0.420	T	Design	265.0 gl	Actual 254.3 gl To Add: 10.7 gl
Slump:	1.00 in	#	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	-1.0 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #1 @ 0900 CARPENTER WB CORBS				TICKET CODE: 1231992 DATE: 08/04/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OFF NORTHBOUND I-75 SERVICE DR NORTH OF CANIFF							MAP PAGE: DT4273B3	TIME: 8:37	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	108	GREG KRDESCH	4834	30.01	10.00	1.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SSFW		10.00	yd	MDOT P1 S35 SLIP FORM WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GBBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature) Kelly J. [Signature] COLLECTED (circle one) CHECK CASH CREDIT				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4834	GRKROESCH	user1	1231992	1231992	8:37	8/4/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SSFW				W2	319889

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1680 lb	16800 lb	16800 lb	0.00%			
2NS-SMR	1490 lb	15496 lb	15480 lb	-0.23%	4.00% M	71 gl	
CMT1-LAA	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	26.6 gl	183.6 gl	183.0 gl	-0.32%		183.0 gl	
OAE-BA	5 oz	316 oz	316 oz	0.13%			
OWRA-PR	16 oz	158 oz	157 oz	-0.51%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	39067 lb	Design W/C: 0.420	Water/Cement: 0.421 T	Design	265.0 gl	Actual	254.3 gl To Add: 10.7 gl
Slump:	1.00 in	# Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	-1.0 gl / yd		



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>8-4-20</u>
PROJECT: <u>Detroit PW-7018</u>	INSPECTOR: <u>Jackie Edwards</u>	
CONTRACTOR: <u>Westside</u>	CONTROL SECTION/MDOT JOB NO.: _____	
CONCRETE SUPPLIER & CITY: <u>McGraw - 7 mile</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>65° Cloudy</u> P.M. _____	TIME ARRIVED: <u>8:45</u> SCHEDULED ARRIVAL TIME: <u>9:00</u> TIME LEFT SITE: <u>10:00</u>	
AGGREGATE CORRECTION FACTOR: <u>.2</u>		

Pour Description: curb on Carpenter - approx to Joseph Campau

Mix Design: P1-SSRW Quantity Placed (yd³): 10.0 Lot Number: _____ Sublot: _____
Grade of Concrete: P1 Batch Quantity (yd³): 10.0 Pour Start: 9:05 Pour End: 9:55

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4834	1231992	8:37	9:05	9:55	1 1/2"	65°	88°	7.0	-	-	001-4

REMARKS

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #4 FORREST SIDENALICS				TICKET CODE: 1232174 DATE: 08/05/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN EAST OF THE LODGE							MAP PAGE: DT4345C3	TIME: 16:15	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	103	JOE CHAPP	2442	41.50	41.50	5.00 in	6.50	1	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-SM	11.00	yd	MDOT P1 S35 MR						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT	DETROIT	M-11					
FLY ASH:									
COARSE AGG:	L6AA-PIN	LAA - PORT INLAND	71-003	COMPANY REPRESENTATIVE (signature) Kelsey D. [Signature]					
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003						
FINE AGG:				COLLECTED (circle one) CHECK CASH CREDIT					
DRIVERS COMMENTS: 4/14/19				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. WESTSIDE CONCRETE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE [Signature]			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
2442	JOCHAPP	user1	1232174	1232174	16:15 8/5/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq Load ID
11.00 yd	P1-SM				W2 320070

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15298 lb	15280 lb	-0.23%	3.00% M	53 gl	
CMT1-LAA	342 lb	3762 lb	3760 lb	-0.32%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	259.0 gl	259.0 gl	-0.01%		259.0 gl	
QAE-BA	5 oz	119 oz	119 oz	0.33%			
OMRLI-PR	26 oz	289 oz	292 oz	0.93%			
HWATER	% #	gl	gl				

Actual Load	42797 lb	Design W/C:	0.451	Water/Cement:	0.452 T	Design	312.4 gl	Actual	312.3 gl	To Add:	0.1 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	0.0 gl / yd				

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#3 FOREST @ 14:45 SIDEWALKS</i>				TICKET CODE: 1232145 DATE: 08/05/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN EAST OF THE LODGE							MAP PAGE: DT4345B3	TIME: 14:04	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	103	JAMAINE KIDD	2438	30.51	30.50	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	% UCM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
PI-SM		11.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
66BFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature) <i>Kelany Thompson</i> X				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING HILL RECLAMATION		47-003	COLLECTED (circle one) CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2438	JAKIDD	user1	1232145	1232145	14:04	8/5/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				W2	320041

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15286 lb	15220 lb	-0.49%	3.00% M	53 gl	
CMT1-LAA	342 lb	3782 lb	3750 lb	-0.32%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	259.0 gl	259.0 gl	-0.01%		259.0 gl	
OAE-BA	5 oz	119 oz	119 oz	-0.10%			
OMRLI-PR	26 oz	289 oz	288 oz	-0.45%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	42757 lb	Design W/C: 0.451	Water/Cement: 0.452	T	Design	312.4 gl	Actual	312.1 gl To Add: 0.3 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	0.0 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2 @ 1130 FOREST SIDEWALK LC</i>				TICKET CODE: 1232107 DATE: 08/05/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN EAST OF THE LODGE							MAP PAGE: DT4345B3	TIME: 11:03	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	103	JOHN CASTRO	2444	33.01	19.50	5.00 in	6.50	1	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-SM	8.50	yd	MDOT P1 S35 MR						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGGFS: FLY ASH:	CMT1-LAA CMGS-CRHS	CEMENT T1 LAFARGE ALPENA SLAG CEMENT ST MARYS CEMENT	ALPENA DETROIT	MDOT PLANT NO.	GRADE OF CONC.				
				M-11					
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING HILL RECLAMATION	71-003 47-003	COMPANY REPRESENTATIVE (signature) <i>Keleey Thompson</i> X		COLLECTED (circle one) CHECK CASH CREDIT			
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2444	JOCASIRO	user1	1232107	1232107	11:03	8/5/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
8.50 yd	P1-SM				W2	320004

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	15130 lb	15120 lb	-0.07%			
2NS-SMR	1350 lb	11877 lb	11820 lb	-0.48%	3.50% M	48 gl	
CMT1-LAA	342 lb	2907 lb	2910 lb	0.10%			
CMGS-CRHS	184 lb	1564 lb	1560 lb	-0.26%			
WAT1	28.4 gl	193.3 gl	193.0 gl	-0.14%		193.0 gl	
OAE-BA	5 oz	92 oz	92 oz	-0.17%			
OMRLI-PR	26 oz	224 oz	228 oz	1.99%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	33041 lb	Design W/C: 0.451	Water/Cement: 0.451	T	Design	241.4 gl	Actual	240.9 gl To Add: 0.5 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	0.0 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: 449792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#1 @ 0920</i> <i>FOREST AVE.</i> <i>SIDENALKS</i>				TICKET CODE: 1232084 08/05/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN EAST OF THE LODGE							MAP PAGE: DT4345B3	TIME: 8:46	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	103	TAMIKO LEE	2353	33.01	11.00	5.00 in	6.50	1	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-SM	11.00	yd	MDOT P1 S35 MR						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature)				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COLLECTED (circle one)				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
FINE AGG:					CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2353	TALEE	user1	1232084	1232084	8:46	8/5/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				W2	319981

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15370 lb	15380 lb	-0.06%	3.50% M	62 gl	
CMT1-LAA	342 lb	3762 lb	3780 lb	0.48%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	250.1 gl	250.0 gl	-0.05%		250.0 gl	
QAE-BA	5 oz	119 oz	119 oz	-0.10%			
OMRL-PR	28 oz	289 oz	284 oz	-1.83%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42851 lb	Design W/C: 0.451	Water/Cement: 0.450 T	Design	312.4 gl	Actual	312.2 gl To Add: 0.2 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	0.0 gl / yd		



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete Company</u>
PROJECT: <u>PN-7018 City Major Roads Name County</u>
CONTRACTOR: <u>Westside Concrete</u>
CONCRETE SUPPLIER & CITY: <u>Mccoig material Detroit</u>
WEATHER: ☒ A.M. <u>Sunny</u> ☐ P.M.
AGGREGATE CORRECTION FACTOR: <u>0.2</u>

D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>8-5-20</u>
INSPECTOR: <u>M. Boarwe</u>	
CONTROL SECTION/MDOT JOB NO.:	
PROJECT ENGINEER: <u>CITY OF DETROIT</u>	
TIME ARRIVED: <u>8:00</u>	
SCHEDULED ARRIVAL TIME: <u>9:00</u>	
TIME LEFT SITE: <u>11:30</u>	

Pour Description: Wayne State University parking Lot H 62 to Lot 44 Forest Street Sidewalk

Mix Design: P1-5m Quantity Placed (yd³): 33.01 Lot Number: — Sublot: —

Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 9:30 Pour End: 10:50

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2353	1232084	8:46	9:30	10:50	4 3/4	68	79	6.6	146.4	0.985	4 QCI

REMARKS



**DRISENGA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CORRECTIVE ACTION FORM

CONTRACTOR: West Side Concrete Company	D&A PROJECT NO.: 2020525-42	DATE: 8-5-20
PROJECT: PW-7018 City Major Roads Wayne County	QUALITY CONTROL TECHNICIAN: Mekhwan Roque	
PROJECT ENGINEER: City of Detroit	CONTROL SECTION/MDOT JOB NO.:	

DESCRIPTION OF REASON FOR CORRECTIVE ACTION:

Truck H 2353 online on site with an air content of 5.0%. Poly. Supplied 5% is outside Specification.

PROPOSED CORRECTIVE ACTION:

Notified McCoig material Batch plant manager who directed the driver to add 1.9% air and entrainment to be re-tested.

CORRECTIVE ACTION TAKEN & ACCEPTED:

Truck H 2353 was re-tested with an air of 6.8% which is inside Specification limit. Poly resumed.

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-701B MAJOR ROADS VARIOUS LOCATIONS <i>AA @ 4:20 FOREST AVG. SIDEWALKS</i>				TICKET CODE: 1232315 DATE: 08/06/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN EAST OF THE LODGE							MAP PAGE: DT4345C3	TIME: 15:56	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	102	BILL HALL	1462	39.00	39.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		8.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COLLECTED (circle one) CHECK CASH CREDIT				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
COMPANY REPRESENTATIVE (signature) <i>Kelley Thompson</i> X									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☒				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
1462	BIHALL	user1		1232315	1232315	15:56	8/6/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
8.00 yd	P1-SM				W2	320208	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14240 lb	0.00%			
2NS-SMR	1350 lb	11124 lb	11120 lb	-0.04%	3.00% M	39 gl	
CMT1-LAA	342 lb	2736 lb	2750 lb	> 0.51%			
CMGS-CRHS	184 lb	1472 lb	1470 lb	-0.14%			
WAT1	28.4 gl	198.4 gl	198.0 gl	-0.19%		196.0 gl	
QAE-BA	5 oz	86 oz	88 oz	-0.31%			
OMRLI-PR	28 oz	210 oz	208 oz	-1.14%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	31234 lb	Design W/C: 0.451	Water/Cement: 0.484	A	Design	227.2 gl	Actual	234.8 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	1.0 gl / yd	To Add:	0.0 gl

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#3 @ 1430 FOREST AVE. SIDEWALKS</i>				TICKET CODE: 1232287 DATE: 08/06/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN EAST OF THE LODGE							MAP PAGE: DT4345C3	TIME: 14:07	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	102	WILLIE WEST	2403	31.01	31.00	5.00 in	6.50	1	
ITEM NAME:	QUANTITY:	UNIT:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-SM	11.00	yd	MDOT P1 S35 MR						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature) <i>Kelley J. Thompson</i> X				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket	Num	Ticket ID	Time	Date
2403	WIWEST	user1	1232287		1232287	14:07	8/6/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
11.00 yd	P1-SM				W2	320180	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15296 lb	15240 lb	-0.36%	3.00% M		53 gl
CMT1-LAA	342 lb	3762 lb	3750 lb	-0.32%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	264.5 gl	264.0 gl	-0.19%			264.0 gl
QAE-BA	5 oz	119 oz	119 oz	-0.10%			
OMRLI-PR	26 oz	289 oz	288 oz	-0.45%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42818 lb	Design W/C: 0.451	Water/Cement: 0.459	A	Design	312.4 gl	Actual 317.2 gl To Add: 0.0 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	0.5 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 FOREST SIDEWALK				TICKET CODE: 1232244 DATE: 08/06/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN EAST OF THE LODGE							MAP PAGE: DT4345B3	TIME: 11:08	
PO NO:	ORDER NO:	DRIVER NAME:	TRUCK NO:	QTY ORDERED:	QTY DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	102	MIKE JOHNSON	2402	33.01	20.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		10.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA CMGS-CRHS	CEMENT T1 LAFARGE ALPENA SLAG CEMENT ST MARYS CEMENT		ALPENA DETROIT	MDOT PLANT NO. M-11	GRADE OF CONC.			
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		71-003 47-003	COMPANY REPRESENTATIVE (signature) Kelsey Thompson X		COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2402	MIJOHNSON	user1	1232244	1232244	11:08	8/6/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SM				W2	320141

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1760 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13905 lb	13840 lb	-0.47%	3.00% M	48 gl	
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	28.4 gl	235.5 gl	235.0 gl	-0.20%		235.0 gl	
QAE-BA	5 oz	108 oz	108 oz	0.16%			
OMRL-PR	26 oz	263 oz	268 oz	1.90%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	36885 lb	Design W/C:	0.451	Water/Cement:	0.451	T	
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	
		Design	284.0 gl	Actual	283.3 gl	To Add:	0.7 gl
					0.0 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #100913 FOREST SIDEWALK				TICKET CODE: 1232211 DATE: 08/06/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN EAST OF THE LODGE							MAP PAGE: DT4345B3	TIME: 8:41	
RO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	102	SIXTO CARRION	4816	33.01	10.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		10.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA CMGS-CRHS	CEMENT T1 LAFARGE ALPENA SLAG CEMENT ST MARYS CEMENT		ALPENA DETROIT	MDOT PLANT NO. M-11	GRADE OF CONC.			
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		71-003 47-003	COMPANY REPRESENTATIVE (signature) <i>Kelley Thompson</i> X		COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
4816	SICARRION	user1	1232211	1232211	1232211	8:41	8/6/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
10.00 yd	P1-SM				W2	320107	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17820 lb	0.11%			
2NS-SMR	1350 lb	13905 lb	13960 lb	-0.32%	3.00% M		48 gl
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	28.4 gl	235.5 gl	236.0 gl	0.23%			236.0 gl
QAE-BA	5 oz	108 oz	108 oz	0.16%			
OMRL-PR	28 oz	263 oz	264 oz	0.38%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	38933 lb	Design W/C: 0.451	Water/Cement: 0.451	A	Design	284.0 gl	Actual	284.4 gl To Add: 0.0 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	0.0 gl / yd		



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westco Concrete</u>	D&A PROJECT NO.: <u>2-20325-0</u>	DATE: <u>8-6-2012</u>
PROJECT: <u>Deerfield Pkwy 70-8</u>	INSPECTOR: <u>Adam D. Smith</u>	
CONTRACTOR: <u>Westco Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>M'Leary Detroit</u>	PROJECT ENGINEER: <u>Chris D. Smith</u>	
WEATHER: A.M. <u>67 Sunny</u> P.M.	TIME ARRIVED: SCHEDULED ARRIVAL TIME: TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR: <u>0.2-3</u>		

Pour Description: Sidewalk on E B Ferry Avenue Skating R Grounds
#110

Mix Design: P1-SW Quantity Placed (yd³): 1.2 Lot Number: Sublot:

Grade of Concrete: P1 Batch Quantity (yd³): 1.2 Pour Start: 9:15 Pour End: 9:45

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
41816	1732211	8:41	9:15		4 3/4	67°	78°	6.8%			4 CL

REMARKS

Fix Curb on E B Ferry

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i># 3 @ 1400</i> <i>TIREMAN</i> <i>SIDEWALKS & CURBS</i>				TICKET CODE: 1232582 DATE: 08/10/20	
DRIVER INSTRUCTION: ON TIREMEN AT ARTERSIAN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4342A3	TIME: 13:23	
RO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	130	WILLIAM EVANS	2900	33.01	33.00	5.00 in	6.00	1	
ITEM NAME:	QUANTITY:	LOOSE	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-DETM	11.00	yd	CITY OF DETROIT P1 MR						
MDOT 1156 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:				M-11					
FLY ASH:				COMPANY REPRESENTATIVE (signature) <i>Kelany J. Thompson</i>					
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	71-003	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT					
INTERM AGG:	2NS-SMR	2NS SPRING HILL RECLAMATION	47-008						
FINE AGG:									
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket	Num	Ticket ID	Time	Date
2900	WIEVANS	user1	1232582			1232582	13:23	8/10/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID		
11.00 yd	P1-DETM				W2	320477		

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	19910 lb	19900 lb	-0.05%			
2NS-SMR	1230 lb	13868 lb	13800 lb	-0.49%	2.50% M	40 gl	
CMT1-LAA	564 lb	6204 lb	6180 lb	-0.39%			
WAT1	30.5 gl	281.2 gl	281.0 gl	-0.08%		281.0 gl	
OMRLI-PR	39 oz	434 oz	436 oz	0.40%			
QAE-BA	6 oz	112 oz	112 oz	-0.15%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	42259 lb	Design W/C: 0.451	Water/Cement: 0.453	T	Design	335.5 gl	Actual	321.3 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.3 gl / yd	To Add: 14.2 gl

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2 @ 1242</i> <i>HA TIREMAN</i> <i>SIDEWALKS & CURBS</i>				TICKET CODE: 1232563 DATE 08/10/20	
DRIVER INSTRUCTION: ON TIREMEN AT ARTERSIAN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4342A3	TIME: 11:52	
PO NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	130	BILL SEARS	4812	33.01	22.00	5.00 in	6.00	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT			
GGGFS:				M-11					
FLY ASH:				COMPANY REPRESENTATIVE (signature) <i>Kelany Thompson</i>					
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	71-003	☒					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003						
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket	Num	Ticket ID	Time	Date
4812	BISEARS	user1	1232563	1232563		11:52	8/10/20	
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID		
11.00 yd	P1-DETM				W2	320458		

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	19910 lb	19900 lb	-0.05%			
2NS-SMR	1230 lb	13868 lb	13820 lb	-0.35%	2.50% M	40 gl	
CMT1-LAA	564 lb	6204 lb	6210 lb	0.10%			
WAT1	30.6 gl	295.0 gl	295.0 gl	0.01%		295.0 gl	
OMRLI-PR	39 oz	434 oz	438 oz	0.40%			
OAE-BA	6 oz	112 oz	112 oz	-0.15%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	42426 lb	Design W/C: 0.451	Water/Cement: 0.451	T	Design	335.5 gl	Actual	335.4 gl To Add: 0.1 gl
Skump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	0.0 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#1 @ 1108</i> <i>TIREMAN</i> <i>SIDEWALKS & CURBS</i>				TICKET CODE: 1232551 DATE 08/10/20	
DRIVER INSTRUCTION: ON TIREMAN AT ARTERSIAN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4342A3	TIME: 10:35	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	130	MIKE CAPLING	4831	33.01	11.00	5.00 in	6.00	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETH		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:				M-11					
FLY ASH:				COMPANY REPRESENTATIVE (signature) <i>Kelley D. [Signature]</i> X					
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	71-003						
INTERM AGG:	2NS-SMR	2NS SPRING HILL RECLAMATION	47-003						
FINE AGG:				COLLECTED (circle one) CHECK CASH CREDIT					
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket	Num	Ticket ID	Time	Date
4831	MICAPLING	user1	1232551			1232551	10:35	8/10/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID		
11.00 yd	P1-DETM				W2	320446		

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	19910 lb	19900 lb	-0.05%			
2NS-SMR	1230 lb	13936 lb	13900 lb	-0.26%	3.00% M	49 gl	
CMT1-LAA	564 lb	6204 lb	6200 lb	-0.06%			
WAT1	30.5 gl	286.9 gl	287.0 gl	0.05%		287.0 gl	
OMRLI-PR	39 oz	434 oz	432 oz	-0.53%			
OAE-BA	6 oz	112 oz	112 oz	0.29%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	42429 lb	Design W/C: 0.451	Water/Cement: 0.452	A	Design	335.5 gl	Actual	335.5 gl To Add: 0.0 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	0.0 gl / yd		



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>20205754A</u>	DATE: <u>8-10-2020</u>
PROJECT: <u>Palace PU 7018</u>	INSPECTOR: <u>Palace Duman</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>City of Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: <u>Sunny</u>	TIME ARRIVED: <u>10:30</u>	
A.M. <u>82°</u>	SCHEDULED ARRIVAL TIME: <u>10:30</u>	
P.M.	TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR: <u>0.2</u>		

Pour Description: Slab on ground for 10' x 10' area - 5' x 4' of Trenches St

Mix Design: P1-DET1 Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____
Grade of Concrete: P1 Batch Quantity (yd³): 33 Pour Start: 10:00 Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4531	1232551	10:35	11:00		4	82	86	7.6	141.6	1.008	4 QCI

REMARKS

W/OMRL-TR, CM-CA

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#3</i> <i>PURBAN</i> <i>SIDEWALKS</i>				TICKET CODE: 1232675 DATE: 08/11/20	
DRIVER INSTRUCTION: ON TIREMEN AT ARTERSIAN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4341E3	TIME: 12:52	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	116	STANFORD PENN	2339	33.01	33.00	5.00 in	6.00	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:					M-11				
FLY ASH:					COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2339	STPENN	user1	1232675	1232675	12:52	8/11/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-DETM				W2	320572

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	19910 lb	19900 lb	-0.05%	2.50% M		
2NS-SMR	1230 lb	13868 lb	13820 lb	-0.35%			40 gl
CMT1-LAA	564 lb	6204 lb	6180 lb	-0.39%			
WAT1	30.5 gl	284.0 gl	284.0 gl	0.01%			284.0 gl
OMRLI-PR	39 oz	434 oz	432 oz	-0.53%			
OAE-BA	6 oz	112 oz	112 oz	-0.15%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	42304 lb	Design W/C:	0.451	Water/Cement:	0.453 T	Design	335.5 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trkn Water:	-1.0 gl / yd
						Actual	324.4 gl To Add: 11.1 gl

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2 @ 1052</i> <i>TIREMAN</i> <i>SIDEWALKS</i>				TICKET CODE: 1232647 DATE: 08/11/20	
DRIVER INSTRUCTION: ON TIREMEN AT ARTERSIAN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4341E3	TIME: 10:15	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	116	WAYNE WALTON	4807	33.01	22.00	5.00 in	6.00	1	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-DETM	11.00	yd	CITY OF DETROIT P1 HR						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGBFS:				N-11					
FLY ASH:				COMPANY REPRESENTATIVE (signature) <i>Relezy J. [Signature]</i> X					
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	71-003						
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING HILL RECLAMATION	47-003						
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	APPROVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	APPROVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
4807	WAWALTON	user1	1232647	1232647	10:15 8/11/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq Load ID
11.00 yd	P1-DETM				W2 320544

Material	Design Qty	Required	Batched	% Var%	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	19910 lb	19900 lb	-0.05%			
2NS-SMR	1230 lb	13888 lb	13820 lb	-0.35%	2.50% M	40 gl	
CMT1-LAA	584 lb	6204 lb	6180 lb	-0.39%			
WAT1	30.5 gl	284.0 gl	284.0 gl	0.01%		284.0 gl	
OMRL-PR	39 oz	434 oz	438 oz	0.40%			
OAE-BA	6 oz	112 oz	112 oz	-0.15%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42304 lb	Design W/C: 0.451	Water/Cement: 0.453 T	Design	335.5 gl	Actual	324.4 gl To Add: 11.1 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.0 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#1 @ 0914</i> <i>TIREMAN</i> <i>SIDEWALK</i>				TICKET CODE: 1232626 DATE: 08/11/20	
DRIVER INSTRUCTION: ON TIREMAN AT ARTERSIAN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4342A3	TIME: 8:35	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	116	SIXTO CARRION	4816	33.01	11.00	5.00 in	6.00	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		11.00	yd	CITY OF DETROIT P1 HR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:					M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature) <i>Relezy J. [Signature]</i>				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING HILL RECLAMATION		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
4816	SICARRION	user1	1232626	1232626	8:35	8/11/20	
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
11.00 yd	P1-DETM				W2	320523	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	19910 lb	19900 lb	-0.05%			
2NS-SMR	1230 lb	13868 lb	13800 lb	-0.49%	2.50% M	40 gl	
CMT1-LAA	564 lb	8204 lb	8210 lb	0.10%			
WAT1	30.5 gl	285.0 gl	285.0 gl	0.01%		285.0 gl	
OMRLI-PR	39 oz	434 oz	432 oz	-0.53%			
OAE-BA	6 oz	112 oz	111 oz	-0.80%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42408 lb	Design W/C: 0.451	Water/Cement: 0.451 T	Design	335.5 gl	Actual	335.3 gl To Add: 0.2 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	0.0 gl / yd	



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete Construction</u>
PROJECT: <u>PN-7018 Detroit</u>
CONTRACTOR: <u>West Side Concrete</u>
CONCRETE SUPPLIER & CITY: <u>McCoig materials, Detroit</u>
WEATHER: <u>(A.M.) cloudy</u>
P.M.
AGGREGATE CORRECTION FACTOR:

D&A PROJECT NO.: <u>2020525-4A</u>	DATE: <u>8-11-20</u>
INSPECTOR: <u>McKehwon BOAYNE</u>	
CONTROL SECTION/MDOT JOB NO.:	
PROJECT ENGINEER: <u>CITY of Detroit</u>	
TIME ARRIVED: <u>8:30</u>	
SCHEDULED ARRIVAL TIME: <u>9:00</u>	
TIME LEFT SITE: <u>11:00</u>	

Pour Description: Tremont St between Piedmont St and
etc, green Road curbs and side walk WB.

Mix Design: P1-DETM Quantity Placed (yd³): 33.01 Lot Number: — Sublot: —

Grade of Concrete: — Batch Quantity (yd³): 33.01 Pour Start: 9:15 Pour End: 11:00

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4816	1232626	8:35	9:15	10:10	5 3/4	78	87	7.0	140.8	1.013	4 GCI

REMARKS

MCCOIG MATERIALS

1441 Springwells Ct. Detroit, MI 48209

PHONE: (734) 357-2124

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#3 @ 1622 FOREST SIDEWALKS</i>			TICKET CODE: 2205496 DATE: 08/12/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN WEST OF HOOVER ----- CITY SLIP -----							MAP PAGE: DT4345B3	TIME: 15:47
PO NO:	ORDER NO:	DRIVER NAME	TRUCK NO:	QTY. ORDERED	QTY. DELIVERED	DESIGN SLUMP	DESIGNED AIR	PLANT NO.
	117	TIM NESS	483B	30.00	30.00	3.00 in	6.50	2
ITEM NAME		QUANTITY	UOM	DESCRIPTION			UNIT PRICE	EXTENDED
P1-SW-B2		8.00	yd	MDOT P1 535 WRA				
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.								
CEMENT: GGGFS: FLY ASH:		CMT1-CRHM CMGS-LA	CEMENT T1 CRH - MISSISSAUGA LAFARGE NORTH AMERICA GGBF		Detroit S. Chicago		MDOT PLANT NO.	GRADE OF CONC.
COARSE AGG: INTERM AGG:		L6AA-PIN	6AA - PORT INLAND		71-003		COMPANY REPRESENTATIVE (signature) <i>Joseph Yahi</i>	
FINE AGG:		2NS-WLB	2NS - WATERLAND BURMEISTER 8		81-093		COLLECTED (circle one) CHECK CASH CREDIT	
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐		
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.		
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X		
						CUSTOMER SIGNATURE		
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.								

Truck 483B	Driver TINNESS	User user	Disp Ticket Num 2205496	Ticket ID 2205496	Time 15:47	Date 8/12/20
Load Size 8.00 yd	Mix Code P1-SW-B2	Returned	Qty	Mix Age	Seq 2W	Load ID 227202

Material Batch:	Design Qty	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
	1	Start: 15:47:04	End: 15:49:55		Time (hh:mm:ss): 00 : 02 : 51				
L6AA-PIN	1780 lb	1780		14240 lb	14120 lb	-0.84%			
2NS-WLB	1350 lb	1350		11124 lb	11040 lb	-0.78%	3.00%	39 gl	
CMT1-CRHM	342.0 lb	342.0		2736.0 lb	2730.0 lb	-0.22%			
CMGS-LA	184.0 lb	184.0		1472.0 lb	1470.0 lb	-0.14%			
WAT1	28.5 gl	28.5		170.8 gl	171.6 gl	0.44%		171.6 gl	-2.3 gl
OAE-BA	5.26 oz	5.26		61.02 oz	61.00 oz	-0.03%			145.00 %
OWRA-PR	15.78 oz	15.78		128.24 oz	128.00 oz	1.39%			

Actual Load	30804 lb	Design W/C:	0.452	Water/Cement:	0.453	A	Design	228.0 gl	Actual	210.1 gl	To Add:	17.9 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load		Trim Water:	-2.3 gl / yd				

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2 @ 1445 MCCOIG FOREST SIDEWALKS</i>				TICKET CODE: 2205477 DATE: 08/12/20	
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN WEST OF WOODWARD ----- CITY SLIP -----							MAP PAGE: DT4345B3	TIME: 13:58	
PO NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	117	ROD HAZELY	3711	33.01	22.00	3.00 in	6.50	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW-B2		11.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-CRHM	CEMENT / T1 CRH - MISSISSAUGA		Detroit	MDOT PLANT NO.		GRADE OF CONC.		
GGBS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. Chicago					
FLY ASH:					COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one)		
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	<i>Joseph Yahi</i>		CHECK CASH CREDIT		
INTERM AGG:	2NS-WLB	2NS - WATERLAND BURMEISTER 0		81-093					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck 3711	Driver ROHAZELY	User user	Disp Ticket Num 2205477	Ticket ID 2205477	Time 13:58	Date 8/12/20
Load Size 11.00 yd	Mix Code P1-SW-B2	Returned	Qty	Mix Age	Seq 2W	Load ID 227183

Material Batch:	Design Qty	Start	SSD	Adj.T	Required	Batched	% Var	% Moisture	Actual Wat	Trim
				End:		Time (hh:mm:ss):				
L6AA-PIN	1780 lb		1780		19580 lb	19520 lb	-0.31%			
2NS-WLB	1350 lb		1350		15370 lb	15360 lb	-0.06%	3.50%	82 gl	
CMT1-CRHM	342.0 lb		342.0		3762.0 lb	3750.0 lb	-0.32%			
CMGS-LA	184.0 lb		184.0		2024.0 lb	2020.0 lb	-0.20%			
WAT1	28.5 gl		28.5		226.0 gl	226.2 gl	0.10%		226.2 gl	-2.3 gl
OAE-BA	5.28 oz		5.28		83.80 oz	84.00 oz	0.12%			145.00 %
OWRA-PR	15.78 oz		15.78		173.58 oz	176.00 oz	1.39%			

Actual	Num Batches:		
Load 42654 lb	Design W/C: 0.452	Water/Cement: 0.453	A
Slump: 3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water: 288.5 gl

Actual 288.5 gl To Add: 25.0 gl
 Note: Manual feed occurred

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-701B MAJOR ROADS VARIOUS LOCATIONS <i>#1 @ 1153 FOREST CURBS & SIDEWALKS</i>				TICKET CODE: 2205454 DATE: 08/12/20		
DRIVER INSTRUCTION: FORREST AND CASS CASS SOUTH OFF WARREN WEST OF WOODWARD ----- CITY SLIP -----							MAP PAGE: DT434583		TIME: 11:23	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:		
	117	ERNEST CHAMBER	4830	33.01	11.00	3.00 in	6.50	2		
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:		
P1-SW-B2		11.00	yd	MDOT P1 S35 WRA						
MDOT 1188 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.										
CEMENT:		CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit		MDOT PLANT NO.		GRADE OF CONC.	
GGBFS:		CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. Chicago					
FLY ASH:							COMPANY REPRESENTATIVE (signature)			
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003				COLLECTED (circle one)	
INTERM AGG:									CHECK CASH CREDIT	
FINE AGG:		2NS-WLB	2NS - WATERLAND BURMEISTER 8		81-093		X <i>Joseph Yahi</i>			
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☒				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE				
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:					
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.										

Truck 4830	Driver ERCHAMBERS	User user	Disp Ticket Num 2205454	Ticket ID 2205454	Time 11:23	Date 8/12/20
Load Size 11.00 yd	Mix Code P1-SW-B2	Returned	Qty	Mix Age	Seq 2W	Load ID 227160

Material	Design Qty	SSD	Adj.T	Required	Batched	% Var	% Moisture	Actual Wat	Trim
Batch:	1	Start: 11:23:55	End: 11:26:58		Time (hh:mm:ss): 00 : 03 : 01				
L6AA-PIN	1780 lb	1780		19580 lb	19480 lb	-0.51%			
2NS-WLB	1350 lb	1350		15370 lb	15320 lb	-0.32%	3.50%	82 gl	
CMT1-CRHM	342.0 lb	342.0		3762.0 lb	3760.0 lb	-0.32%			
CMGS-LA	184.0 lb	184.0		2024.0 lb	2020.0 lb	-0.20%			
WAT1	28.5 gl	28.5		228.0 gl	227.0 gl	0.42%		227.0 gl	-2.3 gl
OAE-BA	5.28 oz	5.28		83.90 oz	83.00 oz	-1.07%			145.00 %
OWRA-PR	15.78 oz	15.78		173.58 oz	168.00 oz	-3.21%			

Actual	Num Batches: 1		
Load	42480 lb	Design W/C: 0.452	Water/Cement: 0.453 A
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load

Design	313.5 gl	Actual	289.0 gl	To Add:	24.5 gl
Trim Water:		-2.3 gl / yd			

Note: Manual feed occurred



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete</u>	D&A PROJECT NO.: <u>2020525-LIA</u>	DATE: <u>08-12-20</u>
PROJECT: <u>PW-7018 CHYOK</u>	INSPECTOR: <u>Mekhemon Borkie</u>	
CONTRACTOR: <u>West Side Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McClurg</u>	PROJECT ENGINEER: <u>CITY OF DETROIT</u>	
WEATHER: <u>Sunny</u>	TIME ARRIVED: <u>10:40</u>	
A.M. <u>Sunny</u>	SCHEDULED ARRIVAL TIME: <u>11:00</u>	
P.M.	TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR:		

Pour Description: Forest Street - between Second Street and
Case Street curb side walk

Mix Design: P1-SUB2 Quantity Placed (yd³): 33.01 Lot Number: — Sublot: —

Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 12:15 Pour End: 12:50

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
41830	220545	11:23	12:15	2:50	3 3/4	86	82	6.0	143.6	0.996	40-1

REMARKS

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 SOUTHFIELD SIDEWALK (3900) BALANCE SENT TO TIREMON 1535 MRB REJECTED 20740 SIDE / APRON				TICKET CODE: 1232935 DATE: 08/13/20	
DRIVER INSTRUCTION: PLYMOUTH AND SOUTHFIELD				20738 20746		DT4270B5 13:53			
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	113	TYRANE WHITE	4807	32.01	32.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		10.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature) <i>Kelley Thompson</i> COLLECTED (circle one) ☒ CHECK: CASH CREDIT				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4807	TYWHITE	user1	1232935	1232935	13:53	8/13/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	320832

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17820 lb	0.11%	3.00% M		
2NS-SMR	1350 lb	13905 lb	13840 lb	-0.47%			48 gl
CMT1-LAA	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	28.4 gl	215.5 gl	215.0 gl	-0.22%		215.0 gl	
QAE-BA	5 oz	121 oz	121 oz	0.02%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	38722 lb	Design W/C: 0.451	Water/Cement: 0.451 T	Design	284.0 gl	Actual	283.3 gl To Add: 20.7 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	-2.0 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2 @ 1300 SOUTHFIELD SIDEWALKS - ADD 1 1/2 GAL / YARD (15)</i>				TICKET CODE: 1232915 DATE: 08/13/20	
DRIVER INSTRUCTION: PLYMOUTH AND SOUTHFIELD ----- CITY SLIP -----						MAP PAGE: DT4270B7		TIME: 11:50	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	113	DANIEL MCCARTHY	2436	33.01	22.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		11.00	yd	MDOT P1 S35 WRA					
MDOT 1165 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Relay Thompson</i>				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
FINE AGG:					COLLECTED (circle one) CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE _____			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2436	DAMCCARTHY	user1	1232915	1232915	11:50	8/13/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SW				W2	320812

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15298 lb	15260 lb	-0.23%	3.00% M		53 gl
CMT1-LAA	342 lb	3782 lb	3750 lb	-0.32%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	231.5 gl	232.0 gl	0.21%			232.0 gl
QAE-BA	5 oz	133 oz	133 oz	-0.43%			
OWRA-PR	16 oz	174 oz	173 oz	-0.33%			
HWATER	% #	gl	gl				

Actual Load	42565 lb	Design W/C:	0.451	Water/Cement:	0.452	T	Design	312.4 gl	Actual	285.3 gl	To Add:	27.1 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load		Trim Water:	-2.5 gl / yd				

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#1 @ 1110 HRS</i> <i>SOUTFIELD</i> <i>CURBS</i>				TICKET CODE: 1232902 DATE: 08/13/20	
DRIVER INSTRUCTION: PLYMOUTH AND SOUTHFIELD ----- CITY SLIP -----							MAP PAGE: DT4270B7	TIME: 10:19	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	113	MIKE JOHNSON	2402	33.01	11.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		11.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)				
INTERM AGG:					<i>Relegh J. Johnson</i>				
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one)				
					X	CHECK CASH CREDIT			
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
2402	MIJOHNSON	user1		1232902	1232902	10:19	8/13/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
11.00 yd	P1-SW				W2	320799	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19800 lb	0.10%			
2NS-SMR	1350 lb	15296 lb	15300 lb	0.03%	3.00% M		53 gl
CMT1-LAA	342 lb	3762 lb	3740 lb	< -0.58%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	237.0 gl	237.0 gl	-0.01%			237.0 gl
OAE-BA	5 oz	133 oz	133 oz	-0.06%			
OWRA-PR	18 oz	174 oz	174 oz	0.24%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42657 lb	Design W/C: 0.451	Water/Cement: 0.453	T	Design	312.4 gl	Actual 290.4 gl To Add: 22.0 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-2.0 gl / yd	



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: WestSide Concrete
PROJECT: Detroit PW 7018
CONTRACTOR: WestSide Concrete
CONCRETE SUPPLIER & CITY: McCoy's Materials Detroit
WEATHER: A.M. mostly sunny P.M.
AGGREGATE CORRECTION FACTOR:

D&A PROJECT NO.: 20205254A	DATE: 08-13-20
INSPECTOR: M. Boyle	
CONTROL SECTION/MDOT JOB NO.:	
PROJECT ENGINEER: City Detroit CA	
TIME ARRIVED:	
SCHEDULED ARRIVAL TIME:	
TIME LEFT SITE:	

Pour Description: Southfield Service Drive NB and Wadsworth Street Corb

Mix Design: P1S35WRA Quantity Placed (yd³): 11.02 Lot Number: Sublot:

Grade of Concrete: P1 Batch Quantity (yd³): 11.02 Pour Start: 11:20 Pour End:

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2402	1232902	10:19	11:20	12:20	3.0	82	82	5.3	143.6	0.9996	49C1

REMARKS

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 @ 1054 LRS TIREMAN SIDEWALKS				TICKET CODE: 1233020 DATE: 08/14/20	
DRIVER INSTRUCTION: ON TIREMAN AT WEST OF EVERGREEN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4342A3	TIME: 10:14	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	110	ANTHONY TAYLOR	2353	33.01	22.00	5.00 in	6.00	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
PI-DETH		11.00	yd	CITY OF DETROIT P1 HR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-CRHS	CRH CEMENT		MDOT PLANT NO.	GRADE OF CONC.				
GGDFS: FLY ASH:				M-11					
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) Kelsey Thompson COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
FINE AGG:									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2353	ANTAYLOR	user1	1233020	1233020	10:14	8/14/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-DETM				W2	320917

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	19910 lb	19900 lb	-0.05%	2.50% M		
2NS-SMR	1230 lb	13868 lb	13840 lb	-0.20%			40 gl
CMT1-CRHS	564 lb	6204 lb	6200 lb	-0.06%			
WAT1	30.5 gl	289.5 gl	289.0 gl	-0.16%			289.0 gl
OMRLI-PR	39 oz	434 oz	432 oz	-0.53%			
OAE-BA	6 oz	102 oz	103 oz	0.62%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	42365 lb	Design W/C: 0.451	Water/Cement: 0.452	T	Design	335.6 gl	Actual	329.5 gl To Add: 6.0 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-0.5 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PM-7018 MAJOR ROADS VARIOUS LOCATIONS #1 @ 0905 TIREM DN SIDEWALKS				TICKET CODE: 1233005 DATE: 08/14/20	
DRIVER INSTRUCTION: ON TIREMEN AT WEST OF EVERGREEN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4342A3	TIME: 8:21	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	110	WAYNE WALTON	4856	33.01	11.00	5.00 in	6.00	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-CRHS	CRH CEMENT	MDOT PLANT NO.		GRADE OF CONC.			
GGBS:				M-11					
FLY ASH:									
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND	71-003		COMPANY REPRESENTATIVE (signature) <i>Rafael J. ...</i> COLLECTED (circle one) CHECK CASH CREDIT			
INTERM AGG:				47-003					
FINE AGG:		2NS-SMR	2NS SPRING MILL RECLAMATION						
DRIVERS COMMENTS:									
						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4856	WAWALTON	user1	1233005	1233005	8:21	8/14/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-DETM				W2	320902

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	19910 lb	19900 lb	-0.05%			
2NS-SMR	1230 lb	13868 lb	13800 lb	-0.48%	2.50% M	40 gl	
CMT1-CRHS	564 lb	6204 lb	6180 lb	< -0.71%			
WAT1	30.5 gl	289.5 gl	289.0 gl	-0.16%		289.0 gl	
OMRLI-PR	39 oz	434 oz	428 oz	-1.45%			
OAE-BA	6 oz	102 oz	102 oz	-0.36%			
H2O	% #	gl	gl				

Actual	Num Batches: 1						
Load	42305 lb	Design W/C: 0.451	Water/Cement: 0.455	T	Design	335.5 gl	Actual 329.3 gl To Add: 6.2 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0	gl / Load	Trim Water:	-0.5 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-701B MAJOR ROADS VARIOUS LOCATIONS <i>#4 @ 1505</i> <i>TIREMAN</i> <i>SIDE WALKS</i>				TICKET CODE: 1233060 DATE: 08/14/20	
DRIVER INSTRUCTION: ON TIREMAN AT WEST OF EVERGREEN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4341D3	TIME: 14:39	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	137	ANTHONY TAYLOR	2353	20.01	20.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		10.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT	DETROIT	M-11					
FLY ASH:				COMPANY REPRESENTATIVE (signature) <i>Relief Thompson</i> COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT					
COARSE AGG	L6AA-PIN	6AA - PORT INLAND	71-003						
INTERM AGG	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003						
FINE AGG:				X					
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
2353	ANTAYLOR	user1	1233060	1233060	14:39 8/14/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq Load ID
10.00 yd	P1-SM				W2 320959

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13838 lb	13820 lb	-0.13%	2.50% M		40 gl
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	28.4 gl	243.6 gl	243.0 gl	-0.23%			243.0 gl
QAE-BA	5 oz	113 oz	113 oz	-0.08%			
OMRLI-PR	26 oz	263 oz	264 oz	0.38%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	38931 lb	Design W/C: 0.451	Water/Cement: 0.451 T	Design	284.0 gl	Actual	283.4 gl To Add: 0.6 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	0.0 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS 3 @ 1340 TIREMAN SIDWALK				TICKET CODE: 1233050 DATE: 08/14/20	
DRIVER INSTRUCTION: ON TIREMAN AT WEST OF EVERGREEN WEST OF SOUTHFIELD RD ----- CITY SLIP -----							MAP PAGE: DT4342A3	TIME: 12:58	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	137	SIXTO CARRION	4816	11.01	10.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		10.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
6GBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Relay Transfer</i>				
INTERM AGG:					☒ COLLECTED (circle one)				
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	☐ CHECK ☐ CASH ☐ CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	☒			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4816	SICARRION	user1	1233050	1233050	12:58	8/14/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SM				W2	320948

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13838 lb	13800 lb	-0.27%	2.50% M		40 gi
CMT1-LAA	342 lb	3420 lb	3430 lb	0.29%			
CMGS-CRHS	184 lb	1840 lb	1840 lb	0.00%			
WAT1	28.4 gi	243.6 gi	243.0 gi	-0.23%			243.0 gi
OAE-BA	5 oz	113 oz	113 oz	-0.52%			
OMRLI-PR	28 oz	263 oz	260 oz	-1.14%			
HWATER	% #	gi	gi				

Actual	Num Batches: 1							
Load	38921 lb	Design W/C: 0.451	Water/Cement: 0.450 T	Design	284.0 gi	Actual	283.3 gi	To Add: 0.7 gi
Slump:	5.00 in	Water In Truck:	0.0 gi	Adjust Water:	0.0 gi / Load	Trim Water:	0.0 gi / yd	



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>westside</u>	D&A PROJECT NO.:	DATE: <u>8-14-2020</u>
PROJECT: <u>Detroit pw 7018</u>	INSPECTOR: <u>Jon Morris 01293676</u>	
CONTRACTOR: <u>Westside</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McCoig Materials - 7 mile</u>	PROJECT ENGINEER:	
WEATHER: A.M. <u>Sunny</u> P.M.	TIME ARRIVED: <u>8:00 AM</u> SCHEDULED ARRIVAL TIME: <u>8:00 AM</u> TIME LEFT SITE: <u>10:15 AM</u>	
AGGREGATE CORRECTION FACTOR: <u>2%</u>		

Pour Description: sidewalk patches multiple locations on Tireman Ave
North + South side. From

Mix Design: pl-DETM Quantity Placed (yd³): 11 Lot Number: Sublot:

Grade of Concrete: pl Batch Quantity (yd³): 11 Pour Start: 9:08 Pour End: 10:00 AM

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
21 7.0 4856	1233005	8:21	9:08	-	2 in	78	83	7.2	-	-	4 GC

REMARKS

Mix pl-DETM contained OAE-BA, and OMLF-PR

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 @ 1230 TIREMAN CURBS				TICKET CODE: 1233159 DATE: 08/17/20	
DRIVER INSTRUCTION: ON TIREMEN WEST OF EVERGREEN // WEST OF SOUTHFIELD RD							MAP PAGE: DT434103	TIME: 11:50	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	131	DANIEL MCCARTHY	2436	8.50	8.50	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW 		8.50	yd	MDOT P1 S35 WRA					
MDOT 1154 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA CMGS-CRHS	CEMENT T1 LAFARGE ALPENA SLAG CEMENT ST MARYS CEMENT		ALPENA DETROIT	MDOT PLANT NO. M-11	GRADE OF CONC.			
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		71-003 47-003	COMPANY REPRESENTATIVE (signature) 		COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
2436	DAMCCARTHY	user1	1233159	1233159	1233159	11:50	8/17/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
8.50 yd	P1-SW				W2	321059	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wet
L6AA-PIN	1780 lb	15130 lb	15120 lb	-0.07%	2.50% M	34 gl	190.0 gl
2NS-SMR	1350 lb	11762 lb	11720 lb	-0.36%			
CMT1-LAA	342 lb	2907 lb	2930 lb	> 0.79%			
CMGS-CRHS	184 lb	1564 lb	1590 lb	> 1.66%			
WAT1	28.4 gl	190.0 gl	190.0 gl	-0.01%			
QAE-BA	5 oz	103 oz	103 oz	0.16%			
OWRA-PR	16 oz	134 oz	134 oz	-0.10%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	32960 lb	Design W/C: 0.451	Water/Cement: 0.448	T	Design	241.4 gl	Actual 224.3 gl To Add: 17.1 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water:		0.0 gl / Load	Trim Water:	-2.0 gl / yd

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #1 @ 0930 TIREMAN CURBS & SIDEWALKS				TICKET CODE: 1233134 DATE 08/17/20	
DRIVER INSTRUCTION: ON TIREMEN WEST OF EVERGREEN // WEST OF SOUTHFIELD RD							MAP PAGE: DT4341D3	TIME: 8:19	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	121	MIKE JOHNSON	2402	33.01	11.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature) 				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	☒ COLLECTED (circle one)				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	☐ CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket ☐ Before Discharge Completed				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	☒ CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2402	MIJOHNSON	user1	1233134	1233134	8:19	8/17/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				W2	321034

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15221 lb	15180 lb	-0.27%	2.50% M	44 gl	
CMT1-LAA	342 lb	3782 lb	3750 lb	-0.32%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	262.4 gl	262.0 gl	-0.16%		262.0 gl	
QAE-BA	5 oz	122 oz	122 oz	0.00%			
OMRI-PR	26 oz	289 oz	288 oz	-0.45%			
HWATER	% #	gl	gl				

Actual Load		Num Batches: 1		Design 312.4 gl		Actual 306.4 gl		To Add: 6.0 gl	
Slump: 5.00 in	Design W/C: 0.451	Water/Cement: 0.452	T	Adjust Water: 0.0 gl / Load	Trim Water: -0.5 gl / yd				

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-701B MAJOR ROADS VARIOUS LOCATIONS #3 @ 1543 WYOMING SIDEWALKS				TICKET CODE: 1233186 DATE: 08/17/20	
DRIVER INSTRUCTION: WYOMING & MCNIHOLS ON MCNICHOLS							MAP PAGE: DT4341D3	TIME: 15:01	
PO NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	121	STANFORD PENN	6634	22.00	22.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) 				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) CHECK CASH CREDIT				
FINE AGG:									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
6634	STPENN	user1	1233186	1233186	15:01	8/17/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				W2	321086

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15221 lb	15180 lb	-0.27%	2.50% M	44 gl	
CMT1-LAA	342 lb	3762 lb	3770 lb	0.21%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	262.4 gl	263.0 gl	0.22%		263.0 gl	
OAE-BA	5 oz	122 oz	122 oz	0.00%			
OMRL-PR	26 oz	289 oz	288 oz	-0.45%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	42770 lb	Design W/C: 0.461	Water/Cement: 0.450	T	Design	312.4 gl	Actual	307.4 gl To Add: 5.0 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	-0.5 gl / yd		



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <i>Westside Concrete</i>	D&A PROJECT NO.: <i>2020525.4A</i>	DATE: <i>8-17-20</i>
PROJECT: <i>PW-7018</i>	INSPECTOR: <i>Joe Kennedy 01268983</i>	
CONTRACTOR: <i>Westside Concrete</i>	CONTROL SECTION/MDOT JOB NO.: <i>PW-7018</i>	
CONCRETE SUPPLIER & CITY: <i>Morgan Detroit</i>	PROJECT ENGINEER:	
WEATHER: A.M. <i>7:27</i> P.M.	TIME ARRIVED: <i>8:30am</i> SCHEDULED ARRIVAL TIME: <i>8:30am</i> TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR: <i>.26</i>		

Pour Description: *Various sidewalk locations on highway one*

Mix Design: *M-SM* Quantity Placed (yd³): Lot Number: Sublot:

Grade of Concrete: *P1* Batch Quantity (yd³): Pour Start: *2:35* Pour End:

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2462	1233134	8:19	9:35		5	72	60	6.7	1433	.989	400

REMARKS

Mix contains M/WC

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#1 @ 0859</i> <i>WYOMING</i> <i>CURBS & SIDEWALKS</i>				TICKET CODE: 2205785 DATE: 08/18/20	
DRIVER INSTRUCTION: ON WYOMING BTW 7 MILE AND MCNICHOLS RD NORTH OF THE LODGE -----							MAP PAGE: 07427181	TIME: 8:20	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	117	WILLIE WEST	2403	33.01	10.00	5.00 in	6.50	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		10.00	yd	MDOT P1 S35 NR					
MDOT 1158 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:		CMT1-CRHM CMGS-LA		CEMENT T1 CRH - MISSISSAUGA LAFARGE NORTH AMERICA GGBF		Detroit S. Chicago		MDOT PLANT NO. GRADE OF CONC.	
COARSE AGG: INTERM AGG:		L6AA-PIN 6AA - PORT INLAND		71-003		01-093		COMPANY REPRESENTATIVE (signature) <i>X Joseph Yahi</i>	
COARSE AGG: INTERM AGG:		2NS-WLB 2NS - WATERLAND BURMEISTER B		01-093		COLLECTED (circle one) CHECK CASH CREDIT		Customer Requested Ticket Before Discharge Completed ☐	
DRIVERS COMMENTS:									
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck 2403	Driver WIWEST	User user	Disp Ticket Num 2205785	Ticket ID 2205785	Time 8:20	Date 8/18/20
Load Size 10.00 yd	Mix Code P1-SM	Returned	Qty	Mix Age	Seq 2W	Load ID 227495

Material Batch:	Design Qty	Start:	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
				End:		Time (hh:mm:ss):	00 : 02	: 16		
L6AA-PIN	1780 lb		1780		17800 lb	17760 lb	-0.22%			
2NS-WLB	1350 lb		1350		14006 lb	13920 lb	-0.62%	3.75%	60 gl	
CMT1-CRHM	342.0 lb		342.0		3420.0 lb	3420.0 lb				
CMGS-LA	184.0 lb		184.0		1840.0 lb	1850.0 lb	+ 0.54%			
WAT1	28.4 gl		28.4	-20.0	197.9 gl	196.8 gl	-0.59%		196.8 gl	-5 gl
OAE-BA	5.28 oz		5.28		55.23 oz	55.00 oz	-0.42%			105.00 %
OMRLI-PR	28 oz		28		283 oz	280 oz	-1.14%			

Actual Load	38812 lb	Design W/C:	0.451	Water/Cement:	0.450	A	Design	284.0 gl	Actual	267.1 gl	To Add:	28.9 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	-20.0	gl / Load	Trim Water:	-0.5	gl /	yd		

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 @ 1339 WYOMING CURBS & SIDEWALKS				TICKET CODE: 2205830 DATE: 08/18/20	
DRIVER INSTRUCTION: ON WYOMING BTW 7 MILE AND MCNICHOLS RD NORTH OF THE LODGE -----							MAP PAGE: DT4271B1	TIME: 13:01	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	117	RONALD PATTERSON	2437	33.01	21.00	5.00 in	6.50	2	
ITEM NAME:	QUANTITY:	UNIT:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
PI-SM	11.00	yd	MDOT PI S35 MR						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. Chicago					
FLY ASH:					COMPANY REPRESENTATIVE (signature)				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COLLECTED (circle one) CHECK CASH CREDIT				
INTERM AGG:	2NS-WLB	2NS - WATERLAND-BURMEISTER-B		81-093					
FINE AGG:					X <i>Joseph Yahi</i>				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck 2437	Driver ROPATTERSON	User user	Disp Ticket Num 2205830	Ticket ID 2205830	Time 13:01	Date 8/18/20			
Load Size 11.00 yd	Mix Code Pl-SM	Returned	Qty	Mix Age	Seq 2W	Load ID 227540			
Material Batch:	Design Qty	SSD Start	Adj.T End	Required	Batched Time (hh:mm:ss)	% Var : 02	% Moisture : 40	Actual Wat	Trim
L8AA-PIN	1780 lb	1780		19580 lb	19520 lb	-0.31%			
2NS-WLB	1350 lb	1350		15370 lb	15240 lb	-0.84%	3.50%	82 gi	
CMT1-CRHM	342.0 lb	342.0		3762.0 lb	3750.0 lb	-0.32%			
CMGS-LA	184.0 lb	184.0		2024.0 lb	2020.0 lb	-0.20%			
WAT1	28.4 gl	28.4		241.4 gl	242.1 gl	0.27%		242.1 gi	-8 gi
OAE-BA	5.26 oz	5.26		80.75 oz	80.00 oz	-1.24%			105.00 %
OMRLI-PR	28 oz	28		289 oz	288 oz	-0.45%			
Actual Load	42572 lb	Design W/C: 0.451	Water/Cement: 0.452	A	Design 312.4 gi	Actual 303.8 gi	To Add: 8.6 gi		
Slump:	5.00 in	Water in Truck: 0.0 gi	Adjust Water: 0.0 gi	/ Load	Trim Water: -0.8 gi	/ yd			

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#3 @ 1615</i> <i>WYOMING</i> <i>CURBS & SIDEWALKS</i>				TICKET CODE 2205855 DATE 08/18/20	
DRIVER INSTRUCTION: ON WYOMING BTW 7 MILE AND MCNICHOLS RD NORTH OF THE LODGE -----							MAP PAGE DT4271B1	TIME 15:33	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	117	KEVIN BROWN	4821	32.01	32.00	5.00 in	6.50	2	
ITEM NAME	QUANTITY	UNIT	DESCRIPTION				UNIT PRICE	EXTENDED	
P1-SM	11.00	yd	MDOT P1 S35 HR						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. Chicago					
FLY ASH:					COMPANY REPRESENTATIVE (signature)				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COLLECTED (circle one) CHECK CASH CREDIT				
INTERM AGG:				81-093					
FINE AGG:	2NS-WLB	2NS - WATERLAND-BURMEISTER 8		81-093	X <i>Joseph Yahi</i>				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP	WATER ADDED	REQUESTED BY	FINAL SLUMP	TESTED AIR	REVOLUTIONS	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT	ARRIVE AT JOB	START POUR	FINISH POUR	LEAVE JOB	ARRIVE PLANT	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck 4821	Driver KEBROWN	User user	Disp Ticket Num 2205855	Ticket ID 2205855	Time 15:33	Date 8/18/20
Load Size 11.00 yd	Mix Code P1-SM	Returned	Qty	Mix Age	Seq 3D	Load ID 227565

Material	Design Qty	Start	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
Batch:	1		15:33:15	End:	15:39:47	Time (hh:mm:ss):	00 : 06	: 32		
L6AA-PIN	1780 lb		1780		19580 lb	19520 lb	-0.31%			
2NS-WLB	1350 lb		1350		15370 lb	15320 lb	-0.32%	3.50%	62 gl	
CMT1-CRHM	342.0 lb		342.0		3782.0 lb	3750.0 lb	-0.32%			
CMGS-LA	184.0 lb		184.0		2024.0 lb	2020.0 lb	-0.20%			
WAT1	28.4 gl		28.4		241.4 gl	240.6 gl	-0.33%		240.6 gl	-8 gl
OAE-BA	5.26 oz		5.26		60.76 oz	61.00 oz	0.41%			105.00 %
OMRLI-PR	26 oz		26		289 oz	288 oz	-0.45%			

Actual	Num Batches:	1
Load	42640 lb	Design W/C: 0.451
Slump:	5.00 in	Water/Cement: 0.452 A
		Design 312.4 gl
		Actual 302.7 gl
		To Add: 9.7 gl
		Water In Truck: 0.0 gl
		Adjust Water: 0.0 gl / Load
		Trim Water: -0.8 gl / yd

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-701B MAJOR ROADS VARIOUS LOCATIONS <i>#401658</i> <i>WYOMING</i> <i>CURBS & SIDEWALKS</i> <i>- ADD 4 GAL H2O</i>				TICKET CODE: 2205857 DATE: 08/18/20		
DRIVER INSTRUCTION: ON WYOMING BTW 7 MILE AND MCNICHOLS RD NORTH OF THE LODGE -----							SLIP PAGE: DT4271B1		TIME: 16:09	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:		
	117	RICO SANDOVAL	3735	41.00	41.00	5.00 in	6.50	2		
ITEM NAME:		QUANTITY:	UNIT:	DESCRIPTION:			UNIT PRICE:	EXTENDED:		
P1-SM		9.00	yd	MDOT P1 S35 HR						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.										
CEMENT:		CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit		MDOT PLANT NO.		GRADE OF CONC.	
GGBF5:		CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. Chicago					
FLY ASH:							COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one)	
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003		<i>Joseph Yalhi</i>		☐ CHECK ☐ CASH ☐ CREDIT	
INTERM AGG:		2NS-WLB	2NS - WATERLAND-BURMEISTER-B		81-093					
DRIVERS COMMENTS:										
								Customer Requested Ticket ☐ Before Discharge Completed		
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.				
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X				
4:35	5					CUSTOMER SIGNATURE				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.										
UNLOAD PROMPTLY: Excess time will be charged to the buyer.										

Truck 3735	Driver RISANDOVAL	User user	Disp Ticket Num 2205857	Ticket ID 2205857	Time 16:09	Date 8/18/20
Load Size 9.00 yd	Mix Code P1-SM	Returned	Qty	Mix Age	Seq 3D	Load ID 227567


Material Batch:	Design Qty	Start	SSD	Adj.T End:	Required	Batched	% Var	%Moisture	Actual Wat	Trm
					16:15:24	Time (hh:mm:ss):	00 : 05	52		
L6AA-PIN	1780 lb		1780		18020 lb	15960 lb	-0.37%			
2NS-WLB	1350 lb		1350		12575 lb	12480 lb	-0.78%	3.50%	51 gl	
CMT1-CRHM	342.0 lb		342.0		3078.0 lb	3070.0 lb	-0.26%			
CMGS-LA	184.0 lb		184.0		1858.0 lb	1850.0 lb	-0.36%			
WAT1	28.4 gl		28.4		197.5 gl	197.0 gl	-0.26%		197.0 gl	-8 gl
QAE-BA	5.26 oz		5.26		49.71 oz	49.00 oz	-1.42%			105.00 %
OMRL-PR	26 oz		26		237 oz	236 oz	-0.30%			

Actual Load	34822 lb	Design W/C:	0.451	Water/Cement:	0.452 A	Design	255.6 gl	Actual	247.6 gl	To Add:	8.0 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trm Water:	-0.8 gl / yd				

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#1 @ 1008 WYOMING CURBS & SIDEWALKS +2</i>				TICKET CODE: 2205891 DATE: 08/19/20	
DRIVER INSTRUCTION: AT 7MILE AND WYOMING, DETROIT SOUTH OF OUTER DRIVE, WEST OF LIVERNOIS NO CITY SLIP							MAP PAGE: DT4345B3	TIME: 9:18	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	114	KYLE CHEESMAN	4822	33.01	14.00	5.00 in	6.50	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SH		11.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CEMENT T1 CRH - MISSISSAUGA		MDOT PLANT NO.		GRADE OF CONC.			
GGGFS:		CMGS-LA		Detroit					
FLY ASH:		LAFARGE NORTH AMERICA GGBF		S. Chicago					
COARSE AGG:		6AA - PORT INLAND		71-003		COMPANY REPRESENTATIVE (signature)  COLLECTED (circle one) CHECK CASH CREDIT			
INTERM AGG:		2NS - WATERLAND DORNHEISTER 0		01-093					
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck 4822	Driver KYCHEESMAN	User user	Disp Ticket Num 2205891	Ticket ID 2205891	Time 9:18	Date 8/19/20			
Load Size 11.00 yd	Mix Code P1-SM	Returned	Qty	Mix Age	Seq 2W	Load ID 227601			
Material Batch:	Design Qty	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
	1	Start: 9:19:00	End:	9:24:42	Time (hh:mm:ss):	00 : 05	: 42		
L6AA-PIN	1780 lb	1780		19580 lb	19400 lb	-0.92%			
2NS-WLB	1350 lb	1350		15295 lb	15200 lb	-0.62%	3.00%	53 gl	
CMT1-CRHM	342.0 lb	342.0		3762.0 lb	3760.0 lb	-0.05%			
CMGS-LA	184.0 lb	184.0		2024.0 lb	2020.0 lb	-0.20%			
WAT1	28.4 gl	28.4		253.1 gl	252.1 gl	-0.37%		252.1 gl	-5 gl
OAE-BA	5.28 oz	5.28		60.75 oz	61.00 oz	0.41%			105.00 %
OMRLI-PR	26 oz	26		289 oz	288 oz	-0.45%			
Actual	Num Batches: 1								
Load	42506 lb	Design W/C: 0.451	Water/Cement:	0.451	A	Design	312.4 gl	Actual	305.2 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0	gl / Load	Trim Water:	-0.5 gl /	To Add:
								yd	7.2 gl

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2 @ 1330</i> <i>WYOMING</i> <i>CURBS & SIDEWALKS</i>				TICKET CODE: 2205931 DATE: 08/19/20	
DRIVER INSTRUCTION: ON WYOMING BETWEEN 7 MILE AND 8 MILE, DETROIT WEST OF LIVERNOIS NO CITY SLIP						MAP PAGE: DT4345B3		TIME: 12:50	
POL NO:	ORDER NO:	DRIVER NAME:	TRUCK NO:	QTY ORDERED:	QTY DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO:	
	114	ANTHONY TAYLOR	2352	33.0	25.00	5.00 in	6.50	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit		MDOT PLANT NO:		GRADE OF CONC:
GBFS:		CMGS-LA	LAFARGE NORTH AMERICA GBF		S. Chicago				
FLY ASH:									
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003		COMPANY REPRESENTATIVE (signature) <i>Joseph Yahi</i>		COLLECTED (circle one) CHECK CASH CREDIT
INTERM AGG:		2NS-WLB	2NS - WATERLAND-BURMEISTER B		81-093				
DRIVERS COMMENTS:									
								Customer Requested Ticket Before Discharge Completed ☐	
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck 2352	Driver ANTAYLOR	User user	Disp Ticket Num 2205931	Ticket ID 2205931	Time 12:50	Date 8/19/20
Load Size 11.00 yd	Mix Code P1-SM	Returned	Qty	Mix Age	Seq 2W	Load ID 227641

Material Batch:	Design Qty	Start	SSD	Adj.T End:	Required	Batched Time (hh:mm:ss)	% Var	%Moisture	Actual Wat	Trim
L6AA-PIN	1780 lb	12:50:35	1780		19580 lb	19580 lb	-0.10%			
2NS-WLB	1350 lb		1350		15285 lb	15240 lb	-0.36%	3.00%	53 gl	
CMT1-CRHM	342.0 lb		342.0		3782.0 lb	3750.0 lb	-0.32%			
CMGS-LA	184.0 lb		184.0		2024.0 lb	2020.0 lb	-0.20%			
WAT1	28.4 gl		28.4		253.1 gl	251.6 gl	-0.58%		251.6 gl	-5 gl
OAE-BA	5.28 oz		5.28		60.75 oz	61.00 oz	0.41%			105.00 %
OMRLI-PR	28 oz		28		289 oz	292 oz	0.93%			

Actual Load	42692 lb	Design W/C:	0.451	Water/Cement:	0.452	A	Design	312.4 gl	Actual	304.8 gl	To Add:	7.8 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0	gl / Load	Trim Water:	-0.5 gl / yd				

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 @ 1356 WYOMING CRABS & SIDEWALKS + 12 GAL K2O				TICKET CODE: 2205963 DATE: 08/19/20	
DRIVER INSTRUCTION: ON WYOMING BETWEEN 7MILE AND 8 MILE(CLOSER TO 8MILE), DETROIT WEST OF LIVERNOIS NO CITY SLIP							MAP PAGE: DT4199B5	TIME: 15:13	
PO NO:	ORDER NO:	DRIVER NAME:	TRUCK NO:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	114	JAMES BASKIN J	4823	36.00	36.00	5.00 in	6.50	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 535 HR					
MDOT 1166 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-CRHM		CEMENT T1 CRH - MISSISSAUGA		Detroit		MDOT PLANT NO.	
GGBFS:		CMGS-LA		LAFARGE NORTH AMERICA GGBF		S. Chicago			
FLY ASH:									
COARSE AGG:		L6AA-PIN		6AA - PORT INLAND		71-003		COMPANY REPRESENTATIVE (signature)	
INTERM AGG:		2NS-WLB		2NS - WATERLAND BURMEISTER B		81-093		COLLECTED (circle one) CHECK CASH CREDIT	
FINE AGG:									
DRIVERS COMMENTS: Customer Requested Ticket Before Discharge Completed									
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			

SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.

UNLOAD PROMPTLY: Excess time will be charged to the buyer.

Truck 4823	Driver JABASKIN	User user	Disp Ticket Num 2205963	Ticket ID 2205963	Time 15:13	Date 8/19/20
Load Size 11.00 yd	Mix Code P1-SM	Returned	Qty	Mix Age	Seq 2W	Load ID 227673

Material	Design Qty	SSD	Adj T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
Batch:	1	Start:	15:13:10	End:	15:16:53	Time (hh:mm:ss):	00 : 03 : 43		
L6AA-PIN	1780 lb			19580 lb	19520 lb	-0.31%			
2NS-WLB	1350 lb			15258 lb	15240 lb	-0.12%	2.75%	49 gl	
CMT1-CRHM	342.0 lb			3762.0 lb	3750.0 lb	-0.32%			
CMGS-LA	184.0 lb			2024.0 lb	2140.0 lb	> 5.73%			
WAT1	28.4 gl			257.5 gl	257.4 gl	-0.04%		257.4 gl	-5 gl
OAE-BA	5.26 oz			60.75 oz	61.00 oz	0.41%			105.00 %
OMRLI-PR	26 oz			289 oz	288 oz	-0.45%			

Actual	Num Batches:	1
Load	42820 lb	Design W/C: 0.451
Slump:	5.00 in	Water/Cement: 0.443 A
	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load
	Design	312.4 gl
	Actual	306.3 gl
	To Add:	6.1 gl
	Trim Water:	-0.5 gl / yd

MCCOIG MATERIALS

500 E. Seven Mile Rd. Detroit, MI 48203

PHONE: (313) 368-1133

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1233316 DATE: 08/20/20	
DRIVER INSTRUCTION: WYOMING SOUTH OF 7 MILE RD							MAP PAGE: DT4199B6	TIME: 14:31	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	113	CARLOS BELL	4807	33.00	33.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONG.			
GGBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) 				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
FINE AGG:									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4807	CABELL	user1	1233316	1233316	14:31	8/20/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				W2	321212

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19600 lb	0.10%			
2NS-SMR	1350 lb	15221 lb	15260 lb	0.25%	2.50% M	45 gl	
CMT1-LAA	342 lb	3762 lb	3780 lb	0.48%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	273.4 gl	273.0 gl	-0.15%		273.0 gl	
OAE-BA	5 oz	124 oz	125 oz	0.08%			
OMRLI-PR	26 oz	289 oz	288 oz	-0.45%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	42964 lb	Design W/C:	0.451	Water/Cement:	0.457 A	Design	312.4 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	0.5 gl / yd
		Actual	317.6 gl	To Add:	0.0 gl		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)


(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1233265 DATE: 08/20/20	
DRIVER INSTRUCTION: WYOMING SOUTH OF 8 MILE							MAP PAGE: DT4341D3	TIME: 9:46	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	113	CHRISTOPHER ML	2446	33.01	11.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GG&FS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)				
INTERM AGG					<i>Kelley Frankowski</i>				
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one)				
					X	CHECK CASH CREDIT			
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2446	CHMURFF	user1	1233265	1233265	9:46	8/20/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				W2	321166

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15221 lb	15160 lb	-0.40%	2.50% M		44 gl
CMT1-LAA	342 lb	3762 lb	3780 lb	0.48%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	267.9 gl	268.0 gl	0.03%			268.0 gl
OAE-BA	5 oz	124 oz	125 oz	0.48%			
OMRLI-PR	26 oz	289 oz	288 oz	-0.45%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42802 lb	Design W/C: 0.451	Water/Cement: 0.450 T	Design	312.4 gl	Actual	312.3 gl To Add: 0.1 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	0.0 gl / yd	



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>4-20-2020</u>
PROJECT: <u>Detroit PW - 7018</u>	INSPECTOR: <u>Patrick Damm</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>City of Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: <u>Sunny</u>	TIME ARRIVED:	
A.M. <u>73</u>	SCHEDULED ARRIVAL TIME:	
P.M.	TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR: <u>0.2</u>		

Pour Description: Submittal - Various locations at side of 14-yearly St from Center St -

Mix Design: PI-SM Quantity Placed (yd³): 11 Lot Number: Sublot:

Grade of Concrete: 91 Batch Quantity (yd³): 33 Pour Start: 10:30 Pour End:

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
3016	1233265	9:46	10:20		4-6	73	78	7.4	135	10.5	

REMARKS

5/1/2020 10:30 AM

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #1 @ 0900 WYOMING SIDEWALK & CURBS				TICKET CODE: 1233399 DATE: 08/21/20	
DRIVER INSTRUCTION: ON WYOMING SOUTH OF 7 MILE RD ----- CITY SLIP -----							MAP PAGE: DT4341D3	TIME: 8:34	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY ORDERED:	QTY DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	110	STEVE JOHNSON	2600	33.01	11.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
PI-SM		11.00	yd	MDOT PI S35 HR					
MDOT 1168 STATEMENT: I hereby certify the concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature) <i>Releby J. [Signature]</i> COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
2600	STJOHNSON	user1	1233399	1233399	1233399	8:34	8/21/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
11.00 yd	P1-SM				W2	321297	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15221 lb	15180 lb	-0.27%	2.50% M	44 gl	
CMT1-LAA	342 lb	3762 lb	3770 lb	0.21%			
CMGS-CRHS	184 lb	2024 lb	2030 lb	0.30%			
WAT1	28.4 gl	267.9 gl	268.0 gl	0.03%		268.0 gl	
OAE-BA	5 oz	116 oz	116 oz	0.24%			
OMRLI-PR	28 oz	269 oz	284 oz	-1.83%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42821 lb	Design W/C: 0.451	Water/Cement: 0.450 T	Design	312.4 gl	Actual	312.4 gl To Add: 0.0 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	0.0 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 WYOMING SIDEWALK & CURBS				TICKET CODE: 1233425 DATE: 08/21/20	
DRIVER INSTRUCTION: ON WYOMING SOUTH OF 7 MILE RD ----- CITY SLIP -----							MAP PAGE: DT4199B7	TIME: 10:48	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	110	ANTHONY OGLESBY	4800	33.01	22.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Kelley J. Matthews</i>				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
FINE AGG:									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	☒			
CUSTOMER SIGNATURE									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
4800	ANOGLESBY	user1	1233425	1233425	1233425	10:48	8/21/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
11.00 yd	P1-SM				W2	321322	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15221 lb	15200 lb	-0.14%	2.50% M		44 gl
CMT1-LAA	342 lb	3762 lb	3760 lb	-0.05%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	273.4 gl	273.0 gl	-0.15%		273.0 gl	
QAE-BA	5 oz	116 oz	116 oz	0.24%			
OMRL-PR	26 oz	289 oz	288 oz	-0.45%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42883 lb	Design W/C: 0.451	Water/Cement: 0.458	A	Design	312.4 gl	Actual 317.4 gl To Add: 0.0 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:		0.0 gl / Load	Trim Water:	0.5 gl / yd

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 @ 1513 WYOMING SIDEWALKS & CURBS				TICKET CODE: 1233462 DATE: 08/21/20	
DRIVER INSTRUCTION: ON WYOMING SOUTH OF 7 MILE RD ----- CITY SLIP -----							MAP PAGE: DT4199B7	TIME: 14:51	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	110	TAMIKO LEE	2353	33.00	33.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 535 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBF5:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature) <i>Reley Thompson</i>				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	☒ COLLECTED (circle one)				
INTERM AGG:					☐ CHECK ☐ CASH ☐ CREDIT				
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	☒			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2353	TALEE	user1	1233462	1233462	14:51	8/21/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				W2	321359

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15221 lb	15200 lb	-0.14%	2.50% M		44 gl
CMT1-LAA	342 lb	3762 lb	3750 lb	-0.32%			
CMGS-CRHS	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	278.9 gl	279.0 gl	0.03%			279.0 gl
OAE-BA	5 oz	118 oz	117 oz	0.87%			
OMRLI-PR	26 oz	289 oz	288 oz	-0.45%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42904 lb	Design W/C: 0.451	Water/Cement: 0.468	A	Design	312.4 gl	Actual 323.4 gl To Add: 0.0 gl
Skump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:		0.0 gl / Load	Trim Water:	1.0 gl / yd



**DRIESENGA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete</u>	D&A PROJECT NO.: <u>2020525-4A</u>	DATE: <u>8-21-20</u>
PROJECT: <u>PW 7018 City of Detroit Major Road</u>	INSPECTOR: <u>Mekeham BOGUE</u>	
CONTRACTOR: <u>West Side Concrete</u>	CONTROL SECTION/MDOT JOB NO.: <u>CITY OF DETROIT</u>	
CONCRETE SUPPLIER & CITY: <u>MCDIG materials, Detroit</u>	PROJECT ENGINEER: <u>CITY OF DETROIT</u>	
WEATHER: <u>A.M. Partly cloudy</u>	TIME ARRIVED: <u>8:20</u>	
	SCHEDULED ARRIVAL TIME: <u>9:00</u>	
AGGREGATE CORRECTION FACTOR:	TIME LEFT SITE: <u>10:30</u>	

Pour Description: Address North-East corner of 18114 Wyoming Ave

Mix Design: P1-sm Quantity Placed (yd³): 33.01 Lot Number: Sublot:
Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 9:20 Pour End: 11:00

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2600	1233399	8:34	9:20	10:20	4 1/2	72	80	6.2	142.8	1.012	4 QCL

REMARKS

The mix contains MIB

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #1 @ 0905 WYOMING SIDEWALKS & CURBS				TICKET CODE: 1233550 08/24/20	
DRIVER INSTRUCTION: ON WYOMING NORTH OF MCNICHLS ----- CITY SLIP -----							MAP PAGE: DT4199B7	TIME: 8:28	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	128	MIKE JOHNSON	2339	33.01	6.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		6.00	yd	MDOT P1 S35 MR					
MDOT 1144 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGBFS:	CMGS-CRHS	SLAG CEMENT ST MARYS CEMENT	DETROIT	M-11					
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	71-003	COMPANY REPRESENTATIVE (signature) <i>Rafael J. [Signature]</i> COLLECTED (circle one) X CHECK CASH CREDIT					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003						
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2339	MIJOHNSON	user1	1233550	1233550	8:28	8/24/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
6.00 yd	P1-SM				W2	321447

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	10680 lb	10700 lb	0.18%			
2NS-SMR	1350 lb	8303 lb	8300 lb	-0.03%	2.50% M		24 gl
CMT1-LAA	342 lb	2052 lb	2050 lb	-0.10%			
CMGS-CRHS	184 lb	1104 lb	1100 lb	-0.36%			
WAT1	28.4 gl	143.1 gl	143.0 gl	-0.09%			143.0 gl
QAE-BA	5 oz	62 oz	62 oz	-0.07%			
SMRLI-PR	26 oz	158 oz	160 oz	1.39%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	23357 lb	Design W/C: 0.451	Water/Cement: 0.451	T	Design	170.4 gl	Actual	167.3 gl To Add: 3.1 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-0.5 gl / yd	



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>8-24-20</u>
PROJECT: <u>Detroit PIW 7018</u>	INSPECTOR: <u>Eric Morris #01395203</u>	
CONTRACTOR: <u>Westside concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>M/eng materials - Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>clear</u> P.M.	TIME ARRIVED: <u>8:45</u> SCHEDULED ARRIVAL TIME: <u>9:00</u> TIME LEFT SITE: <u>10:00</u>	
AGGREGATE CORRECTION FACTOR: <u>0.290</u>		

Pour Description: Sidewalk across lot on 2nd widening rd from south of Curtis st

Mix Design: PL-3M Quantity Placed (yd³): 6 Lot Number: Sublot:

Grade of Concrete: P1 Batch Quantity (yd³): 6 Pour Start: 9:15 Pour End: 9:45

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2339	1233550	8:28	9:15	9:45	4 1/4	77	85	5.8	1426	1.00	4/0, 1

REMARKS

mix contains ARWR