



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete</u>	D&A PROJECT NO.: <u>2020525-4A</u>	DATE: <u>07-15-20</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>M. BOGAYUE</u>	
CONTRACTOR: <u>West Side Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>Mccoig materials, Warren</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: <u>(A.M.) Sunny</u> P.M.	TIME ARRIVED: <u>10:00</u> SCHEDULED ARRIVAL TIME: <u>10:00</u> TIME LEFT SITE: <u>011:30</u>	
AGGREGATE CORRECTION FACTOR: <u>0.2</u>		

Pour Description: North-west corner of Carpenter St and Gallagher St. Hand-tramels

Mix Design: P1-Sm Quantity Placed (yd³): 33.01 Lot Number: — Sublot: —

Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 10:05 Pour End: 10:50

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4410	14138408	9:22	10:05	10:50	6 1/4	82	83	7.0	139.2	1.03	4 of 1

REMARKS

