



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>7-20-20</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>Eric Morris #01395263</u>	
CONTRACTOR: <u>West side concrete</u>	CONTROL SECTION/MDOT JOB NO.: <u> </u>	
CONCRETE SUPPLIER & CITY: <u>Mingo Materials - Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>clear</u> P.M. <u> </u>	TIME ARRIVED: <u>11:00</u> SCHEDULED ARRIVAL TIME: <u>11:00</u> TIME LEFT SITE: <u>11:45</u>	
AGGREGATE CORRECTION FACTOR: <u> </u>		

Pour Description: Sidewalk on W Grand Blvd East of Dexter ave

Mix Design: P1-SM Quantity Placed (yd³): 11 Lot Number: Sublot:
Grade of Concrete: P1 Batch Quantity (yd³): 11 Pour Start: 11:00 Pour End: 11:34

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2403	2203932	10:28	11:00	11:34	4 1/2	77	84	6.1	141.8	1.00	40, 1

REMARKS

