



DRIESENKA & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <i>Westside Concrete</i>	D&A PROJECT NO.: <i>2020525.4A</i>	DATE: <i>7-30-20</i>
PROJECT: <i>Detroit PW-7018</i>	INSPECTOR: <i>Joe Kennedy 01268983</i>	
CONTRACTOR: <i>Westside Concrete</i>	CONTROL SECTION/MDOT JOB NO.: <i>PW-7018</i>	
CONCRETE SUPPLIER & CITY: <i>McCoy Detroit</i>	PROJECT ENGINEER:	
WEATHER: A.M. <i>Sunny 71st</i> P.M.	TIME ARRIVED: SCHEDULED ARRIVAL TIME: TIME LEFT SITE: <i>8:45am</i>	
AGGREGATE CORRECTION FACTOR: <i>.2%</i>		

Pour Description: *various curb locations on e.b. carpenter*

Mix Design: *P1-SW* Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____
Grade of Concrete: *P1* Batch Quantity (yd³): _____ Pour Start: *8:00am* Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2352	1231688	7:25	8:00		2	71	84	5.5	1435	.944	400

REMARKS

