



DRIESENKA & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>8-3-20</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>Jake Richards</u>	# <u>01362857</u>
CONTRACTOR: <u>Westside</u>	CONTROL SECTION/MDOT JOB NO.: <u>—</u>	
CONCRETE SUPPLIER & CITY: <u>McCoy - 7mi Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>7:20 Partly Cloudy</u> P.M.	TIME ARRIVED: <u>8:30</u> SCHEDULED ARRIVAL TIME: <u>9:00</u> TIME LEFT SITE: <u>9:50</u>	
AGGREGATE CORRECTION FACTOR: <u>.2</u>		

Pour Description: Carpenter Run Joseph Pamparo to
Conant

Mix Design: P1-SSEW Quantity Placed (yd³): 10.0 Lot Number: — Sublot: —
Grade of Concrete: P1 Batch Quantity (yd³): 10.0 Pour Start: 9:15 Pour End: 9:50

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
QA 6.0 4831	1231889	8:40	9:15	9:50	1 1/2"	75°	80°	6.2	140.4	1.027	GC1-4

REMARKS

