



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>8-4-20</u>
PROJECT: <u>Detroit PW-7018</u>	INSPECTOR: <u>Jackie Richards</u>	
CONTRACTOR: <u>Westside</u>	CONTROL SECTION/MDOT JOB NO.: <u> </u>	
CONCRETE SUPPLIER & CITY: <u>McCoy 7 mile</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>65° Cloudy</u> P.M. <u> </u>	TIME ARRIVED: <u>8:45</u> SCHEDULED ARRIVAL TIME: <u>9:00</u> TIME LEFT SITE: <u>10:00</u>	
AGGREGATE CORRECTION FACTOR: <u>.2</u>		

Pour Description: Quib on carpenter - Doghouse to Joseph Campan

Mix Design: P1-SSFW Quantity Placed (yd³): 10.0 Lot Number: Sublot:
Grade of Concrete: P1 Batch Quantity (yd³): 10.0 Pour Start: 9:05 Pour End: 9:55

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
GA 4834	1231992	8:37	9:05	9:55	1 1/2"	65°	88°	7.0	-	-	001-4

REMARKS

