



DRIESEN & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Wages de Concrete</u>	D&A PROJECT NO.: <u>2020025-1</u>	DATE: <u>8-6-2020</u>
PROJECT: <u>Detour PW-7018</u>	INSPECTOR: <u>ACE = 0.67%</u> <u>Dennis Snyder</u>	
CONTRACTOR: <u>Wages de Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>Micoig - Deloit</u>	PROJECT ENGINEER: <u>City of Deloit</u>	
WEATHER: A.M. <u>67 / Sunny</u> P.M.	TIME ARRIVED: SCHEDULED ARRIVAL TIME: TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR: <u>0.2-6</u>		

Pour Description: Sidewalk on E B Forest Avenue Starting at 1110

Mix Design: P1 S4 Quantity Placed (yd³): 10 Lot Number: Sublot:

Grade of Concrete: P1 Batch Quantity (yd³): 10 Pour Start: 9:15 Pour End: 9:45

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4816	1232211	8:41	9:15		4 3/4	67°	78°	6.8%			4 CL

REMARKS

P1 S4 CONCRETE & P1 S4