



**DRIESINGA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: West Side Concrete Construction.
PROJECT: PW-7018 Detroit
CONTRACTOR: West Side Concrete
CONCRETE SUPPLIER & CITY: McCoig materials, Detroit
WEATHER: (A.M.) cloudy P.M.
AGGREGATE CORRECTION FACTOR:

D&A PROJECT NO.: 2020525-4A	DATE: 8-11-20
INSPECTOR: Mekehan Boyle	
CONTROL SECTION/MDOT JOB NO.:	
PROJECT ENGINEER: City of Detroit	
TIME ARRIVED: 8:30	
SCHEDULED ARRIVAL TIME: 9:00	
TIME LEFT SITE: 11:00	

Pour Description: Tireman St between Piedmont St and Evergreen Road curbs and side walk WB.

Mix Design: P1-DETM Quantity Placed (yd³): 33.01 Lot Number: Sublot:

Grade of Concrete: Batch Quantity (yd³): 33.01 Pour Start: 9:15 Pour End: 11:00

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4816	1232626	8:35	9:15	10:10	5 3/4	78	87	7.0	140.8	1.013	4QC1

REMARKS