



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete</u>	D&A PROJECT NO.: <u>2020525-LA</u>	DATE: <u>08-12-20</u>
PROJECT: <u>Pnt-7018 City of Detroit Major Roads</u>	INSPECTOR: <u>Mekeem Boraie</u>	
CONTRACTOR: <u>West Side Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McCoy's Detroit</u>	PROJECT ENGINEER: <u>CITY OF DETROIT</u>	
WEATHER: A.M. <u>Sunny</u> P.M.	TIME ARRIVED: <u>10:40</u> SCHEDULED ARRIVAL TIME: <u>11:00</u> TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR:		

Pour Description: Forest Street - between Second Street and Chase Street curb side walk

Mix Design: P1-SUB2 Quantity Placed (yd³): 33.01 Lot Number: — Sublot: —

Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 12:15 Pour End: 12:50

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
41830	220545	11:23	12:15	2:50	8 3/4	86	82	6.0	143.6	0.996	40-1

REMARKS

