



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>WestSide Concrete</u>
PROJECT: <u>Detroit PW 7018</u>
CONTRACTOR: <u>WestSide Concrete</u>
CONCRETE SUPPLIER & CITY: <u>MCCOIG materials Detroit</u>
WEATHER: A.M. <u>mostly sunny</u> P.M.
AGGREGATE CORRECTION FACTOR:

D&A PROJECT NO.: <u>2020525-4A</u>	DATE: <u>08-13-20</u>
INSPECTOR: <u>M. BOAYNE</u>	
CONTROL SECTION/MDOT JOB NO.:	
PROJECT ENGINEER: <u>City Detroit OK</u>	
TIME ARRIVED:	
SCHEDULED ARRIVAL TIME:	
TIME LEFT SITE:	

Pour Description: Southfield Service Drive NB and Wadsworth Street Corb

Mix Design: P1S35WRA Quantity Placed (yd³): 11.00 Lot Number: Sublot:
Grade of Concrete: p1 Batch Quantity (yd³): 11.00 Pour Start: 11:20 Pour End:

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2402	1232902	10:19	11:20	12:20	3.0	82	82	5.3	143.6	0.9996	4 @ 1

REMARKS

