



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>westside</u>	D&A PROJECT NO.: <u>-</u>	DATE: <u>8-14-2020</u>
PROJECT: <u>Detroit pw 7018</u>	INSPECTOR: <u>Jon Morris 01293676</u>	
CONTRACTOR: <u>Westside</u>	CONTROL SECTION/MDOT JOB NO.: <u>-</u>	
CONCRETE SUPPLIER & CITY: <u>McCoig Materials - 7 mile</u>	PROJECT ENGINEER: <u>-</u>	
WEATHER: A.M. <u>Sunny</u> P.M. <u>-</u>	TIME ARRIVED: <u>8:00 AM</u> SCHEDULED ARRIVAL TIME: <u>8:00 AM</u> TIME LEFT SITE: <u>10:15 AM</u>	
AGGREGATE CORRECTION FACTOR: <u>.2%</u>		

Pour Description: sidewalk patches multiple locations on Tireman Ave
North + South side. From

Mix Design: pl-DETM Quantity Placed (yd³): 11 Lot Number: _____ Sublot: _____

Grade of Concrete: pl Batch Quantity (yd³): 11 Pour Start: 9:08 Pour End: 10:00 AM

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
<u>QA 70 4856</u>	<u>1233005</u>	<u>8:21</u>	<u>9:08</u>	<u>-</u>	<u>2 in</u>	<u>78</u>	<u>83</u>	<u>7.2</u>	<u>-</u>	<u>-</u>	<u>4QCI</u>

REMARKS

Mix pl-DETM contained OAE-BA, and OMRW-PR