



DRIESENKA & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>8-17-20</u>
PROJECT: <u>PW-7018</u>	INSPECTOR: <u>Joe Kennedy/01268983</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.: <u>PW-7018</u>	
CONCRETE SUPPLIER & CITY: <u>Melroe - Detroit</u>	PROJECT ENGINEER:	
WEATHER: A.M. <u>July 72°</u> P.M.	TIME ARRIVED: <u>8:30am</u> SCHEDULED ARRIVAL TIME: <u>8:30am</u> TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR: <u>.250</u>		

Pour Description: Various sidewalk locations on highway

Mix Design: P1-SM Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____
Grade of Concrete: P1 Batch Quantity (yd³): _____ Pour Start: 8:35 Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2402	1233134	8:19	9:35		5	72	80	6.7	143.5	.989	4ac

REMARKS

Mix contains MWR