

CONCRETE FIELD QA/QC INSPECTION REPORT

Project: PW 7018		Mix Type: PNC		Theo. Unit Weight:		Air Spec.: 5.5-8.5%	
Contractor: FNC		Mix ID: P-NCOM		Theo. Yield:		Slump Spec.: 6" max	
Consultant: CCT		Lot No.:		Supplier: McCoig		Temp. Spec.: 50°-90°F	
Tester: Jan Ragin		Sublot No.:		Plant: 2		Time Spec.: 60 min max	
Signature: Jan Ragin		Date: 8-21-2020					

Test No.	Ticket No.	Yds./Cum.	No. of Cylinders	Batch Time	Empty Time	Air Content	Slump	Concrete Temp	Air Temp.	Unit Weight	Yield
QC-1	2206093	6/6	0	9:53		7.2%	4.5"	79°	81°		
QC-2	2206104	6/12	4	11:11		6.8%	4.25"	81°	84°		

General Location:

Test No.	Cylinder ID	Location:
QC-2	Set 1	WB Tireman, East of Artesian

Total Volume:

Comments:

Client: FNC

Date: 8-21-2020

CCT No.:

Page: