



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>WestSide Concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>8-21-20</u>
PROJECT: <u>PW 7018 City of Detroit Major Road</u>	INSPECTOR: <u>Mekeham Boone</u>	
CONTRACTOR: <u>WestSide Concrete</u>	CONTROL SECTION/MDOT JOB NO.: <u>CITY OF DETROIT</u>	
CONCRETE SUPPLIER & CITY: <u>MCCOIG materials, Detroit</u>	PROJECT ENGINEER: <u>CITY OF DETROIT</u>	
WEATHER: <u>A.M. Partly cloudy</u>	TIME ARRIVED: <u>8:20</u>	
P.M.	SCHEDULED ARRIVAL TIME: <u>9:00</u>	
AGGREGATE CORRECTION FACTOR:	TIME LEFT SITE: <u>10:30</u>	

Pour Description: Address North-East corner of 18414 Wyoming Ave

Mix Design: P1-sm Quantity Placed (yd³): 33.01 Lot Number: — Sublot: —
Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 9:20 Pour End: 11:00

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2600	1233399	8:34	9:20	10:20	4 1/2	72	80	6.2	1428	1.012	4 QCL

REMARKS

The mix contain MR