



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>8-24-20</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>Eric Morris #01393203</u>	
CONTRACTOR: <u>Westside concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>Mccoys materials - Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>clear</u> P.M.	TIME ARRIVED: <u>8:45</u> SCHEDULED ARRIVAL TIME: <u>9:00</u> TIME LEFT SITE: <u>10:00</u>	
AGGREGATE CORRECTION FACTOR: <u>0.2%</u>		

Pour Description: Sidewalk various locations on Wyoming Rd from south of
Curtis st

Mix Design: Pl-SM Quantity Placed (yd³): 6 Lot Number: _____ Sublot: _____

Grade of Concrete: P1 Batch Quantity (yd³): 6 Pour Start: 9:15 Pour End: 9:45

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2339	1233550	8:28	9:15	9:45	4 1/4	77	85	5.8	1426	1.00	4QC1

REMARKS

mix contains MRWR