



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside</u>	D&A PROJECT NO.: <u>20205254A</u>	DATE: <u>10 15-10</u>
PROJECT: <u>Detroit Pw 7018</u>	INSPECTOR: <u>Jackie Richards</u>	# <u>01362857</u>
CONTRACTOR: <u>Westside</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McCoy - 7 mi</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>5:30 Cloudy</u> P.M.	TIME ARRIVED: <u>7:45</u> SCHEDULED ARRIVAL TIME: <u>8:00</u> TIME LEFT SITE: <u>8:35</u>	
AGGREGATE CORRECTION FACTOR: <u>.2</u>		

Pour Description: sidewalks + curb on Carpenter going NE from
T-75

Mix Design: P1-SW Quantity Placed (yd³): 100 Lot Number: — Sublot: —
Grade of Concrete: P1 Batch Quantity (yd³): 100 Pour Start: 8:05 Pour End: 8:35

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4815	1238414	728	805		3"	59	66	62	140.8	1.019	WC-4

REMARKS