



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>
PROJECT: <u>Detroit PU-7018</u>
CONTRACTOR: <u>Westside Concrete</u>
CONCRETE SUPPLIER & CITY: <u>McCaig - Detroit</u>
WEATHER: <u>Cloudy</u> A.M. <u>59</u> P.M.
AGGREGATE CORRECTION FACTOR: <u>0.2</u>

D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>10-21-2020</u>
INSPECTOR: <u>Patrick Drumm</u>	
CONTROL SECTION/MDOT JOB NO.: _____	
PROJECT ENGINEER: <u>City of Detroit</u>	
TIME ARRIVED: SCHEDULED ARRIVAL TIME: TIME LEFT SITE:	

Pour Description: Curb & Sidewalk - From Fleming St to McDougall - Various location on Carpenter St

Mix Design: P1-SW Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____
Grade of Concrete: P1 Batch Quantity (yd³): 33 Pour Start: 9:05 Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2445	1238821	8:32	9:05		2 1/2	57	65	7.3	144.8	.991	4 QCI

REMARKS

