



DRIESENKA & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>2020535-LA</u>	DATE: <u>10-29-20</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>ACE # 0107556</u> <u>Dennis Snyder</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McCaughey Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>44°F Cloudy</u> P.M.	TAG NUMBERS: <u>Arrival - 8:20am</u>	

Pour Description: Sidewalk @ Tremont + Ashton

Mix Design: P1.50 Quantity Paid (yd³): Lot Number: Sublot:

Grade of Concrete: D1 Batch Quantity (yd³): 8.0 Pour Start: 9:15 Pour End: 9:45am

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2446	1239277	8:33	9:5	945	4	40	60	5.5%	146.0	999	400

REMARKS

Holland

Grand Rapids

Kalamazoo

Detroit