



DRIESENKA & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: Westside Concrete	D&A PROJECT NO.: 2020525.4A	DATE: 10/30/20
PROJECT: PW-7018 City of Detroit Major Roads	INSPECTOR: Matthew Magee	
CONTRACTOR: Westside Concrete	CONTROL SECTION/MDOT JOB NO.: _____	
CONCRETE SUPPLIER & CITY: McCaig Materials - Detroit	PROJECT ENGINEER: City of Detroit	
WEATHER: A.M. Overcast P.M.	TIME ARRIVED: 8:15 am SCHEDULED ARRIVAL TIME: 9:00 am TIME LEFT SITE: 10:00 am	
AGGREGATE CORRECTION FACTOR: 0.2%		

Pour Description: Curb and sidewalk sections on Tireman Ave between Ashton Ave and Brace St

Mix Design: PI-SM Quantity Placed (yd³): 8 Lot Number: _____ Sublot: _____
Grade of Concrete: PI Batch Quantity (yd³): 8 Pour Start: 9:18 Pour End: 9:55

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
QA 5.8 2350	1239696	8:24	9:18	9:55	4.5	39	54	5.7	145.6	.988	4 QCI

REMARKS

Mix contains a MFWR