



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT:	WestSide Concrete
PROJECT:	PW-7018 CITY OF Detroit MAJOR ROADS
CONTRACTOR:	WestSide Concrete
CONCRETE SUPPLIER & CITY:	McCoig materials Detroit
WEATHER:	A.M. mostly cloudy
AGGREGATE CORRECTION FACTOR:	0.20

D&A PROJECT NO.:	DATE:
2020525-4A	11-10-20
INSPECTOR:	
McKehwan Boayue	
CONTROL SECTION/MDOT JOB NO.:	
PROJECT ENGINEER:	
Detroit CITY OF	
TIME ARRIVED: 8:30	
SCHEDULED ARRIVAL TIME: 9:00	
TIME LEFT SITE: 10:30	

Pour Description: Side walk curb and Adm Ramp South-West
and South-East corner of Tireman St / Penrod St

Mix Design: P1-SW Quantity Placed (yd³): 33.01 Lot Number: — Sublot: —
Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 9:05 Pour End: 10:30

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4800	817233	8:21	9:05	10:30	4 3/4	65	67	7.1	1420	1.017	4QC1

REMARKS

